

## ERROR DETECTION

● : flashing

— : Off

### OUTDOOR UNIT

	LED 1	LED 2	LED 3
Communication error (outdoor unit to indoor unit A)	● 1 time	—	—
Communication error (outdoor unit to indoor unit B)	—	● 1 time	—
Communication error (outdoor unit to indoor unit C)	—	—	● 1 time
Discharge pipe thermistor	● 2 times	—	—
Outdoor unit, heat exchanger thermistor (middle)	● 3 times	—	—
Outdoor thermistor error	● 4 times	—	—
2-way valve thermistor (indoor unit A)	● 5 times	—	—
2-way valve thermistor (indoor unit B)	—	● 5 times	—
2-way valve thermistor (indoor unit C)	—	—	● 5 times
3-way valve thermistor (indoor unit A)	● 6 times	—	—
3-way valve thermistor (indoor unit B)	—	● 6 times	—
3-way valve thermistor (indoor unit C)	—	—	● 6 times
Compressor thermistor error	● 7 times	—	—
Heatsink thermistor error	● 8 times	—	—
High pressure switch 1 error	● 9 times	—	—
High pressure switch 2 error	● 10 times	—	—
Indoor unit capacity error	● 11 times	—	—
Trip detection	● 12 times	—	—
Compressor rotor position detection error	● 13 times	—	—
Trip terminal L error	● 14 times	—	—
Outdoor unit fan motor error	● 15 times	—	—
Outdoor unit PCB microcomputer communication error	● 17 times	—	—
Discharge temperature error	● 18 times	—	—
Compressor temperature error	● 19 times	—	—
4-way valve error	● 20 times	—	—
Outdoor unit PCB model information error	● 21 times	—	—
Active filter error, PFC circuit error	● 22 times	—	—