

- **EN INSTALLATION AND OPERATION MANUAL**
- ES MANUAL DE INSTALACIÓN Y FUNCIONAMIENTO
- DE INSTALLATIONS- UND BETRIEBSHANDBUCH
- FR MANUEL D'INSTALLATION ET DE FUNCTIONNEMENT
- IT MANUALE D'INSTALLAZIONE E D'USO

- PT MANUAL DE INSTALAÇÃO E DE FUNCIONAMENTO
- DA BRUGER- OG MONTERINGSVEJLEDNING
- NL INSTALLATIE- EN BEDIENINGSHANDLEIDING
- **SV** HANDBOK FÖR INSTALLATION OCH ANVÄNDING
- ΕL ΕΓΧΕΙΡΙΔΙΟΕΓΚΑΤΑΣΤΑΣΗΣΚΑΙΛΕΙΤΟΥΡΓΙΑΣ

REMOTE CONTROLLER PC-ARF



ΕN

Specifications in this manual are subject to change without notice in order that HITACHI may bring the latest innovations to their customers.

Whilst every effort is made to ensure that all specifications are correct, printing errors are beyond Hitachi's control; Hitachi cannot be held responsible for these errors.

ES

Las especificaciones de este manual están sujetas a cambios sin previo aviso a fin de que HITACHI pueda ofrecer las últimas innovaciones a sus clientes.

A pesar de que se hacen todos los esfuerzos posibles para asegurarse de que las especificaciones sean correctas, los errores de impresión están fuera del control de HITACHI, a quien no se hará responsable de ellos.

DE

Bei den technischen Angaben in diesem Handbuch sind Änderungen vorbehalten, damit HITACHI seinen Kunden die jeweils neuesten Innovationen präsentieren kann.

Sämtliche Anstrengungen wurden unternommen, um sicherzustellen, dass alle technischen Informationen ohne Fehler veröffentlicht worden sind. Für Druckfehler kann HITACHI jedoch keine Verantwortung übernehmen, da sie außerhalb ihrer Kontrolle liegen.

FR

Les caractéristiques publiées dans ce manuel peuvent être modifiées sans préavis, HITACHI souhaitant pouvoir toujours offrir à ses clients les dernières innovations.

Bien que tous les efforts sont faits pour assurer l'exactitude des caractéristiques, les erreurs d'impression sont hors du contrôle de HITACHI qui ne pourrait en être tenu responsable.

IT

Le specifiche di questo manuale sono soggette a modifica senza preavviso affinché HITACHI possa offrire ai propri clienti le ultime novità.

Sebbene sia stata posta la massima cura nel garantire la correttezza dei dati, HITACHI non è responsabile per eventuali errori di stampa che esulano dal proprio controllo.

ΡT

As especificações apresentadas neste manual estão sujeitas a alterações sem aviso prévio, de modo a que a HITACHI possa oferecer aos seus clientes, da forma mais expedita possível, as inovações mais recentes.

Apesar de serem feitos todos os esforços para assegurar que todas as especificações apresentadas são correctas, quaisquer erros de impressão estão fora do controlo da HITACHI, que não pode ser responsabilizada por estes erros eventuais.

DA

Specifikationerne i denne vejledning kan ændres uden varsel, for at HITACHI kan bringe de nyeste innovationer ud til kunderne. På trods af alle anstrengelser for at sikre at alle specifikationerne er korrekte, har Hitachi ikke kontrol over trykfejl, og Hitachi kan ikke holdes ansvarlig herfor.

NL

De specificaties in deze handleiding kunnen worden gewijzigd zonder verdere kennisgeving zodat HITACHI zijn klanten kan voorzien van de nieuwste innovaties.

ledere poging wordt ondernomen om te zorgen dat alle specificaties juist zijn. Voorkomende drukfouten kunnen echter niet door Hitachi worden gecontroleerd, waardoor Hitachi niet aansprakelijk kan worden gesteld voor deze fouten.

sv

Specifikationerna i den här handboken kan ändras utan föregående meddelande för att HITACHI ska kunna leverera de senaste innovationerna till kunderna.

Vi på Hitachi gör allt vi kan för att se till att alla specifikationer stämmer, men vi har ingen kontroll över tryckfel och kan därför inte hållas ansvariga för den typen av fel.

EL

Οι προδιαγραφές του εγχειριδίου μπορούν να αλλάξουν χωρίς προειδοποίηση, προκειμένου η ΗΙΤΑCΗΙ να παρέχει τις τελευταίες καινοτομίες στους πελάτες της.

Αν και έχει γίνει κάθε προσπάθεια προκειμένου να εξασφαλιστεί ότι οι προδιαγραφές είναι σωστές, η Hitachi δεν μπορεί να ελέγξει τα τυπογραφικά λάθη και, ως εκ τούτου, δεν φέρει καμία ευθύνη για αυτά τα λάθη.



This product shall not be mixed with general house waste at the end of its life and it shall be retired according to the appropriated local or national regulations in a environmentally correct way.

Due to the refrigerant, oil and other components contained in Air Conditioner, its dismantling must be done by a professional installer according to the applicable regulations.

Contact to the corresponding authorities for more information.



Éste producto no se debe eliminar con la basura doméstica al final de su vida útil y se debe desechar de manera respetuosa con el medio ambiente de acuerdo con los reglamentos locales o nacionales aplicables.

Debido al refrigerante, el aceite y otros componentes contenidos en el sistema de aire acondicionado, su desmontaje debe realizarlo un instalador profesional de acuerdo con la normativa aplicable.

Para obtener más información, póngase en contacto con las autoridades competentes.

VORSICHT

Dass Ihr Produkt am Ende seiner Betriebsdauer nicht in den allgemeinen Hausmüll geworfen werden darf, sondern entsprechend den geltenden örtlichen und nationalen Bestimmungen auf umweltfreundliche Weise entsorgt werden muss.

Aufgrund des Kältemittels, des Öls und anderer in der Klimaanlage enthaltener Komponenten muss die Demontage von einem Fachmann entsprechend den geltenden Vorschriften durchgeführt werden.

Für weitere Informationen setzen Sie sich bitte mit den entsprechenden Behörden in Verbindung.

Ne doit pas être mélangé aux ordures ménagères ordinaires à la fin de sa vie utile et qu'il doit être éliminé conformément à la réglementation locale ou nationale, dans le plus strict respect de l'environnement.

En raison du frigorigène, de l'huile et des autres composants que le climatiseur contient, son démontage doit être réalisé par un installateur professionnel conformément aux réglementations en vigueur.

Indicazioni per il corretto smaltimento del prodotto ai sensi della Direttiva Europea 2002/96/EC e Dlgs 25 luglio 2005 n.151 Il simbolo del cassonetto barrato riportato sull' apparecchiatura indica che il prodotto alla fine della propria vita utile deve essere raccolto separatamente dagli altri rifiuti.

L'utente dovrà, pertanto, conferire l'apparecchiatura giunta a fine vita agli idonei centri di raccolta differenziata dei rifiuti elettronici ed elettrotecnici, oppure riconsegnarla al rivenditore al momento dell' acquisto di una nuova apparecchiatura di tipo equivalente. L'adeguata raccolta differenziata delle apparecchiature dismesse, per il loro avvio al riciclaggio, al trattamento ed allo smaltimento ambientalmente compatibile, contribuisce ad evitare possibili effetti negativi sull' ambiente e sulla salute e favorisce il riciclo dei materiali di cui è composta l'apparecchiatura.

Non tentate di smontare il sistema o l'unità da soli poichè ciò potrebbe causare effetti dannosi sulla vostra salute o sull'ambiente. Vogliate contattare l'installatore, il rivenditore, o le autorità locali per ulteriori informazioni.

Lo smaltimento abusivo del prodotto da parte dell'utente può comportare l'applicazione delle sanzioni amministrative di cui all'articolo 50 e seguenti del D.Lgs. n. 22/1997.

O seu produto não deve ser misturado com os desperdícios domésticos de carácter geral no final da sua duração e que deve ser eliminado de acordo com os regulamentos locais ou nacionais adequados de uma forma correcta para o meio ambiente. Devido ao refrigerante, ao óleo e a outros componentes contidos no Ar condicionado, a desmontagem deve ser realizada por um instalador profissional de acordo com os regulamentos aplicáveis.

Contacte as autoridades correspondentes para obter mais informações.

At produktet ikke må smides ud sammen med almindeligt husholdningsaffald, men skal bortskaffes i overensstemmelse med de gældende lokale eller nationale regler på en miljømæssig korrekt måde.

Da klimaanlægget indeholder kølemiddel, olie samt andre komponenter, skal afmontering foretages af en fagmand i overensstemmelse med de gældende bestemmelser.

Kontakt de pågældende myndigheder for at få yderligere oplysninger.

Dit houdt in dat uw product niet wordt gemengd met gewoon huisvuil wanneer u het weg doet en dat het wordt gescheiden op een milieuvriendelijke manier volgens de geldige plaatselijke en landelijke reguleringen.

Vanwege het koelmiddel, de olie en andere onderdelen in de airconditioner moet het apparaat volgens de geldige regulering door een professionele installateur uit elkaar gehaald worden.

Neem contact op met de betreffende overheidsdienst voor meer informatie.

Det innebär att produkten inte ska slängas tillsammans med vanligt hushållsavfall utan kasseras på ett miljövänligt sätt i enlighet med gällande lokal eller nationell lagstiftning.

Luftkonditioneringsaggregatet innehåller kylmedium, olja och andra komponenter, vilket gör att det måste demonteras av en fackman i enlighet med tillämpliga regelverk.

Ta kontakt med ansvarig myndighet om du vill ha mer information.

Σημαίνει ότι το προϊόν δεν θα πρέπει να αναμιχθεί με τα διάφορα οικιακά απορρίμματα στο τέλος του κύκλου ζωής του και θα πρέπει να αποσυρθεί σύμφωνα με τους κατάλληλους τοπικούς ή εθνικούς κανονισμούς και με τρόπο φιλικό προς το περιβάλλον. Λόγω του ψυκτικού, του λαδιού και άλλων στοιχείων που περιέχονται στο κλιματιστικό, η αποσυναρμολόγησή του πρέπει να γίνει

λόγω του φυκιτικού, του λαοίου και αλλών στοιχειών που περιεχονταί στο κλιματιστικό, η αποσυναρμολογηση του πρεπεί να γίνει από επαγγελματία τεχνικό και σύμφωνα με τους ισχύοντες κανονισμούς.

Για περισσότερες λεπτομέρειες, επικοινωνήστε με τις αντίστοιχες αρχές.

⊿

DANGER - Hazards or unsafe practices which COULD result in severe personal injuries or death.

PELIGRO – Riesgos o prácticas poco seguras que PODRÍAN producir lesiones personales e incluso la muerte.

GEFAHR – Gefährliche oder unsichere Anwendung, die zu schweren Körperverletzungen oder zum Tod führen kann.

DANGER – Utilisation dangereuse ou sans garantie de sécurité qui PEUT provoquer de sévères blessures personnelles ou la mort.

PERICOLO – Pericoli o azioni pericolose che POTREBBERO avere come esito lesioni fisiche gravi o il decesso.

PERIGO – Riesgos o prácticas poco seguras que PUEDEN producir lesiones personales e incluso la muerte

FARE – Farer eller farlig brug, som KAN resultere i alvorlig personskade eller dødsfald.

GEVAAR - Gevaren of onveilige praktijken die ernstig persoonlijk letsel of de dood tot gevolg KUNNEN hebben.

FARA – Risker eller osäkra tillvägagångssätt som KAN leda till svåra personskador eller dödsfall.

ΚΙΝΑΥΝΟ – Κίνδυνοι ή επικίνδυνες πρακτικές, οι οποίες ΜΠΟΡΕΙ να έχουν ως αποτέλεσμα σοβαρές σωματικές βλάβες ή θάνατο.

\mathbb{A}

CAUTION - Hazards or unsafe practices which COULD result in minor personal injury or product or property damage.

PRECAUCIÓN – Riesgos o prácticas poco seguras que PODRÍAN provocar lesiones personales de menor importancia o daños en el producto u otros bienes.

VORSICHT – Gefährliche oder unsichere Anwendung, die geringfügigen Personen-, Produkt- oder Sachschaden verursachen kann.

PRECAUTION – Utilisation dangereuse ou sans garantie de sécurité qui PEUT provoquer des blessures mineures ou des dommages au produit ou aux biens.

ATTENZIONE – Pericoli o azioni pericolose che POTREBBERO avere come esito lesioni fisiche minori o danni al prodotto o ad altri beni.

CUIDADO – Perigos e procedimentos perigosos que PODERÃO PROVOCAR danos pessoais ligeiros ou danos em produtos e bens.

FORSIGTIG - Farer eller farlig brug, som KAN resultere i mindre skade på personer, produkt eller ejendom.

LET OP – Gevaren of onveilige praktijken die licht persoonlijk letsel of beschadiging van het product of eigendommen tot gevolg KUNNEN hebben.

VARSAMHET – Risker eller farliga tillvägagångssätt som KAN leda till mindre personskador eller skador på produkten eller på egendom.

ΠΡΟΣΟΧΗ – Κίνδυνοι ή επικίνδυνες πρακτικές, οι οποίες ΜΠΟΡΕΙ να έχουν ως αποτέλεσμα την πρόκληση ελαφρών σωματικών βλαβών ή καταστροφή περιουσίας.

[**i**]

NOTE – The text following this symbol contains information or instructions that may be of use or that require a more thorough explanation.

NOTA – El texto que sigue a este símbolo contiene información o instrucciones que pueden ser de utilidad o requeridas para ampliar una explicación.

HINWEIS – Der diesem Symbol folgende Text enthält konkrete Informationen und Anleitungen, die nützlich sein können oder eine tiefergehende Erklärung benötigen.

REMARQUE – Les textes précédés de ce symbole contiennent des informations ou des indications qui peuvent être utiles, ou qui méritent une explication plus étendue.

NOTA – I testi preceduti da questo simbolo contengono informazioni o indicazioni che possono risultare utili o che meritano una spiegazione più estesa.

NOTA – Os textos precedidos deste símbolo contêm informações ou indicações que podem ser úteis, ou que merecem uma explicação mais detalhada.

BEMÆRK – Den tekst, der følger efter dette symbol, indeholder oplysninger eller anvisninger, der kan være til nytte, eller som kræver en mere grundig forklaring.

OPMERKING – De teksten waar dit symbool voorstaat bevatten nuttige informatie en aanwijzingen, of informatie en aanwijzingen meer uitleg behoeven.

OBS – Texten efter denna symbol innehåller information och anvisningar som kan vara användbara eller som kräver en noggrannare förklaring.

ΣΗΜΕΙΩΣΗ – Το κείμενο που ακολουθεί αυτό το σύμβολο περιέχει πληροφορίες ή οδηγίες που μπορεί να φανούν χρήσιμες ή που απαιτούν μια πιο ενδελεχή εξήγηση.

INDEX

- 1. SAFETY SUMMARY
- 2. INSTALLATION WORK
- 3. ELECTRICAL WIRING
- 4. SWITCH NAMES AND FUNCTIONS
- 5. CHECKING PROCEDURE
- 6. FUNCTION SELECTION AND SETTING
- 7. ELEVATING GRILLE SETTING/CANCELLATION
- 8. LOUVER SETTING
- 9. CONTACT INFORMATION REGISTRATION
- 10.CHECK MENU
- **11. OPERATION METHOD**
- **12.SETTING METHOD**
- 13.0PERATION
- 14.MENU OPERATION
- 15.HELP MENU
- 16.0THER INDICATIONS

INHALTSVERZEICHNIS

- 1. SICHERHEITSÜBERSICHT
- 2. INSTALLATION
- 3. KABELANSCHLUSS
- 4. SCHALTERNAMEN UND -FUNKTIONEN
- 5. PRÜFVERFAHREN
- 6. FUNKTION AUSWAHL UND EINSTELLUNG
- 7. LUFTGITTER HOCH/RUNTER EINSTELLEN/ ABBRECHEN
- 8. LUFTLAMMENEINSTELLUNG
- 9. KONTAKTINFORMATION REGISTRIERUNG
- 10.PRÜFMENÜ
- 11. BEDIENVERFAHREN
- 12. EINSTELLVERFAHREN
- 13.BETRIEB
- 14.BETRIEBSMENÜ
- 15.HILFE-MENÜ
- **16.ANDERE ANZEIGEN**

INDICE

- 1. PRECAUZIONI PER LA SICUREZZA
- 2. INSTALLAZIONE
- 3. COLLEGAMENTO DELLO SCHEMA ELETTRICO
- 4. NOMI E FUNZIONI DEI TASTI
- 5. PROCEDURA DI CONTROLLO
- 6. SELEZIONE E IMPOSTAZIONE FUNZIONE
- 7. IMPOSTAZIONE/ANNULLAMENTO SOLLEVAMENTO GRIGLIA
- 8. IMPOSTAZIONE DEFLETTORE
- 9. REGISTRAZIONE INFORMAZIONI DI CONTATTO
- **10.MENU DI CONTROLLO**
- 11. METODO DI FUNZIONAMENTO
- 12.METODO DI IMPOSTAZIONE
- 13.FUNZIONAMENTO
- 14.FUNZIONAMENTO MENU
- **15.HELP MENU**
- 16.ALTRE INDICAZIONI

ÍNDICE

- 1. RESUMEN DE SEGURIDAD
- 2. INSTALACIÓN
- 3. CABLEADO ELÉCTRICO
- 4. NOMBRE Y FUNCIONES DE LOS INTERRUPTORES
- 5. PROCEDIMIENTO DE COMPROBACIÓN
- 6. SELECCIÓN DE FUNCIONES Y AJUSTES
- 7. AJUSTE/CANCELACIÓN REJILLA ARRIBA/ABAJO
- 8. AJUSTE DEL DEFLECTOR
- 9. REGISTRO DE INFORMACIÓN DE CONTACTO
- 10.MENÚ DE COMPROBACIÓN
- 11. MÉTODO DE FUNCIONAMIENTO
- 12.MÉTODO DE AJUSTE
- 13.FUNCIONAMIENTO
- 14.FUNCIONAMIENTO DEL MENÚ
- 15.MENÚ AYUDA
- **16.OTRAS INDICACIONES**

INDEX

- 1. SOMMAIRE DES DISPOSITIFS DE SÉCURITÉ
- 2. PROCÉDURE D'INSTALLATION
- 3. CÂBLAGE ÉLECTRIQUE
- 4. NOMS ET FONCTIONS DES TOUCHES
- 5. PROCÉDURE DE VÉRIFICATION
- 6. SÉLECTION DES FONCTIONS ET RÉGLAGE
- 7. RÉGLAGE/ANNULATION DE LA GRILLE HAUT/BAS
- 8. RÉGLAGE INDIVIDUEL VOLET
- 9. ENREGISTREMENT DE L'INFORMATION DE CONTACT
- **10.MENU MODE DE VÉRIFICATION**
- 11. MÉTHODE DE FONCTIONNEMENT
- 12.MÉTHODE DE RÉGLAGE
- 13.FONCTIONNEMENT
- 14.MENU FONCTIONNEMENT
- 15.MENU D'AIDE
- **16.AUTRES INDICATIONS**

ÍNDICE

- 1. RESUMO DA SEGURANÇA
- 2. TRABALHO DE INSTALAÇÃO
- 3. LIGAÇÕES ELÉCTRICAS
- 4. NOMES E FUNÇÕES DE BOTÕES
- 5. PROCEDIMENTO DE VERIFICAÇÃO
- 6. SELECÇÃO E AJUSTE DA FUNÇÃO
- 7. AJUSTE/CANCELAMENTO DA GRELHA DE ELEVAÇÃO
- 8. AJUSTE DO DEFLECTOR
- 9. REGISTO DA INFORMAÇÃO DE CONTACTO
- **10.MENU DE VERIFICAÇÃO**
- 11. MÉTODO DE FUNCIONAMENTO
- 12.MÉTODO DE AJUSTE
- 13.FUNCIONAMENTO

15.MENU DE AJUDA

16.OUTRAS INDICAÇÕES

14. FUNCIONAMENTO DO MENU

INDHOLDSFORTEGNELSE

- 1. OVERSIGT OVER SIKKERHED
- 2. MONTERINGSARBEJDE
- 3. ELEKTRISK LEDNINGSFØRING
- 4. KNAPPERNES BETEGNELSER OG FUNKTIONER
- 5. KONTROLPROCEDURE
- 6. FUNKTIONSVALG OG INDSTILLING
- 7. HÆVERIST INDSTILLING/ANNULLERING
- 8. NDSTILLING AF SPJÆLD
- 9. REGISTRERING AF KONTAKTINFORMATION
- 10.KONTROLMENU
- 11.DRIFTSMETODE
- 12.INDSTILLINGSMETODE
- 13.DRIFT
- 14.MENU DRIFT
- 15.MENUEN HJÆLP
- **16.ANDRE INDIKATIONER**

INNEHÅLLSFÖRTECKNING

- 1. SÄKERHETSSAMMANFATTNING
- 2. INSTALLATIONSARBETE
- 3. ELEKTRISKA LEDNINGAR
- 4. KNAPPAR OCH FUNKTIONER
- 5. KONTROLLPROCEDUR
- 6. FUNKTIONSVAL OCH INSTÄLLNING
- 7. INSTÄLLNING/ANNULLERING AV DET HÖJ- OCH SÄNKBARA GALLRET
- 8. SPJÄLLINSTÄLLNING
- 9. REGISTRERING AV KONTAKTINFORMATION
- 10.KONTROLLMENY
- 11. DRIFTMETOD
- 12.INSTÄLLNINGSMETOD
- 13.DRIFT
- 14.DRIFTSMENY
- 15.HJÄLPMENY
- 16. ÖVRIGA INDIKATIONER

INHOUDSOPGAVE

- 1. VEILIGHEIDSSAMENVATTING
- 2. INSTALLATIEWERK
- 3. ELEKTRISCHE BEDRADING
- 4. SCHAKELAARS: NAMEN EN FUNCTIES
- 5. CONTROLEPROCEDURE
- 6. FUNCTIES SELECTEREN EN INSTELLEN
- 7. HET HEFFEN VAN HET ROOSTER/ANNULEREN
- 8. LAMELINSTELLING
- 9. CONTACTGEGEVENS REGISTEREN
- 10.CONTROLEMENU
- 11. BEDIENINGSMETHODE
- **12.DE MODUS INSTELLEN**
- 13.BEDIENING
- 14.WERKING VAN HET MENU
- 15.HULPMENU
- **16.OVERIGE WEERGAVES**

EYPETHPIO

- 1. ΣΥΝΟΠΤΙΚΕΣ ΠΡΟΦΥΛΑΞΕΙΣ ΑΣΦΑΛΕΙΑΣ
- 2. ΕΡΓΑΣΙΕΣ ΕΓΚΑΤΑΣΤΑΣΗΣ
- 3. ΗΛΕΚΤΡΙΚΗ ΚΑΛΩΔΙΩΣΗ
- 4. ΟΝΟΜΑΤΑ ΔΙΑΚΟΠΤΩΝ ΚΑΙ ΛΕΙΤΟΥΡΓΙΕΣ
- ΔΙΑΔΙΚΑΣΙΑ ΕΛΕΓΧΟΥ
 ΕΠΙΛΟΓΗ ΛΕΙΤΟΥΡΓΙΑΣ ΚΑΙ ΡΥΘΜΙΣΗ
- 7. ΡΥΘΜΙΣΗ/ΑΚΥΡΩΣΗ ΣΧΑΡΑΣ ΑΝΥΨΩΣΗΣ
- 8. ΡΥΘΜΙΣΕΙΣ ΠΕΡΣΙΔΑΣ
- 9. ΕΓΓΡΑΦΗ ΠΛΗΡΟΦΟΡΙΩΝ ΕΠΑΦΗΣ
- 10.ΜΕΝΟΥ ΕΛΕΓΧΟΥ 11. ΤΡΟΠΟΣ ΛΕΙΤΟΥΡΓΙΑΣ 12. ΤΡΟΠΟΣ ΡΥΘΜΙΣΗΣ 13.ΛΕΙΤΟΥΡΓΙΑ
- 14.ΜΕΝΟΥ ΛΕΙΤΟΥΡΓΙΑΣ 15.ΜΕΝΟΥ ΒΟΗΘΕΙΑΣ 16.ΑΛΛΕΣ ΕΝΔΕΙΞΕΙΣ

EN	English	Original version
ES	Español	Versión traducida
DE	Deutsch	Übersetzte Version
FR	Français	Version traduite
IT	Italiano	Versione tradotta
PT	Português	Versão traduzidal
DA	Dansk	Oversat version
NL	Nederlands	Vertaalde versie
SV	Svenska	Översatt version
EL	ΕΛΛΗΝΙΚΑ	Μεταφρασμένη έκδοση

1 SAFETY SUMMARY

HITACHI cannot anticipate every possible circumstance that might involve a potential hazard.

▲ DANGER

- DO NOT pour water into the remote controller. This product is equipped with electrical parts. If poured, it will cause a serious electrical shock.
- DO NOT perform installation work and electrical wiring connection by yourself. Contact your HITACHI distributor or dealer and ask them for installation work and electrical wiring by service person.

- DO NOT install the indoor unit, outdoor unit, controller and cable at such places as;
 - Where there is oil vapor and the oil is dispersed.
 - Where the hot springs are near (in a sulfuric environment).
 - Where generation, flowing, staying or leaking of flammable gas is detected.
 - Where the sea is near (in the salty environment).
 - An acid or alkaline environment.
- DO NOT install the indoor unit, outdoor unit, controller and cable within approximately 3 meters from strong electromagnetic wave radiators such as medical equipment. In case that the controller is installed in a place where there is electromagnetic wave radiation, shield the controller and cables by covering with the steel box and running the cable through the metal conduit tube.
- In case that there is electric noise at the power source for the indoor unit, provide a noise filter.
- Use specified cables to connect between indoor unit and remote control switch. Selecting incorrect cables may lead to fire or electrical shock.

2 INSTALLATION WORK

2.1 SELECTION OF INSTALLATION PLACE

Select a suitable place for handling and determine the installation place of the controller with the customer's acceptance.

Do not install the controller at such places as:

- Where children can touch.
- Where the air from the air conditioner is directly discharged.

Especially in case that a Remote Controller thermostat is used, select the installation place in consideration with the following points:

- Where the average room temperature is detectable.
- Where the thermostat is not exposed directly to the sun.
- Where there is no source of heat.
- Where the thermostat is not affected with the outdoor air by opening and closing doors.

Prior to the installation work, ensure that foundation is flat, level and sufficiently strong and then fix the unit securely. If the foundation is not strong enough, it may lead to injuries caused by falling of the product, electrical shock or fire.



- The installer and system specialist shall comply with local regulations or standards for the safety. The following standards may be applicable, if local regulations are not available. International Organization for Standardization, ISO5149 or European Standard, EN378 or Japan Standard, KHKS0010.
- Perform electrical work according to the Installation Manual. As for the electrical wiring work and check, turn OFF the main power supply before opening/closing the service cover of indoor unit. If service cover is opened with main power supply left on, it may result in an electrical shock.
- It is assumed that this control remote will be operated and serviced by English speaking people. If this is not the case, the customer should add safety such as and operating signs in the native language for non English speakers.
- This manual should be considered as a permanent part of the air conditioning equipment and should remain with the air conditioning equipment.
- This appliance must be used only by adult and capable people, having received the technical information or instructions to handle this appliance properly and safely.
- Children should be supervised to ensure that they do not play with the appliance.
- Important: read and understand this manual before using this remote controller.

If you have any questions, contact your HITACHI distributor or dealer.

2.2 BEFORE INSTALLATION

Check the contents and the number of the accessories in the packing.



Remote control switch for operation control



2 screws M4x16L for fixing the holding bracket onto the wall



1 Operation Manual

2.3 INSTALLATION SPACE

In case of installing the controllers in vertical line, keep a distance more than 50mm between the controllers vertically.

If the distance is insufficient, the controller can not be taken out.



2.4 INSTALLATION PROCEDURES

1 Insert the edge of the slotted screwdriver into the groove at the bottom of the holding bracket, push and turn the slotted screwdriver and then remove the remote control switch from the holding bracket.



- 2 Attach the remote control switch to the holding bracket and connect the cable as follows:
 - In Case of Exposing Remote Control Cable

2

Fix the holding bracket onto the wall with screws (accessory).



Attach the stopper (plastic band) to the cable at the inside of the draw-out hole.



- When Using Switch Box
- a. Prepare field-supplied Implanted Switch Box

(JIS Box). (JIS C 8336-1988)

The following 5 types are available.

- 1. Switch Box for 1 Switch (Without Cover)
- 2. Switch Box for 2 Switches (Without Cover)
- 3. Switch Box for 1 Switch (With Cover)
- 4. Switch Box for 2 Switches (With Cover)
- 5. Outlet Box (With Cover)



b. Lead the cable through the conduit tube in the wall.



c. Peel the insulation at the end of the cable and clamp the M3 solderless terminals (field-supplied).



Connect the terminals

3 ELECTRICAL WIRING

Wiring Example (Using a twist pair cable with shield tube)



Always make sure to turn off the power of the indoor unit when performing electrical wiring work. Performing electrical wiring work with the power on can damage the circuit boards of the indoor unit and the remote control switch.

Remote control cable <option> Model: PRC-x K

3



The number of x indicates the length (m) of the cable (x=2, 3, 5, 8, 10, 15, 20, 30, 50, 75, 100).

The cable of 30m and over is available by ordering. (Contact the closest branch of HITACHI Appliances, Inc.).

- **3** Attach the remote control switch to the holding bracket. Be careful not to pinch the cable when attaching it.
- 4 Remove the protection film from the liquid crystal display.



i) NOTE

- Use a 0.3 to 0.75mm² cable for connecting. The maximum total cable length is 30m. If the total cable length exceeds 30m, use a twist pair cable with shield tube (1P 0.75mm²). In that case, the maximum total cable length is 500m. If using in combination with the control timer, the allowable total cable length is up to 100m. The use of a cable other than that specified above can cause of malfunction due to effects of noise.
- Keep a distance more than 30cm between the transmission line (remote control switch cable and transmission wires) and power source of the indoor units. If not, the air-conditioner may not operate properly or malfunction may occur due to effect of power source noise.
- In case of simultaneously controlling multiple indoor units, set the refrigerant cycle numbers and addresses of the indoor units without overlapping.
- Refer to the Technical Catalog provided with each indoor unit when performing electrical wiring work between the remote control switch and indoor units for setting the refrigerant cycle number and the indoor unit address.
- No gap shall exist between the remote control switch cable and hole of the remote control switch case. If there is a gap, cover the gap with vinyl tape. If not, malfunction may occur due to entrance of water droplets or insects.
- In case of operating with two remote control switches (Main and Sub), set the main and sub remote control switches by selecting the appropriate function with the remote control switches according to the chapter Function selection and setting. After setting it, turn off the power supply of all the indoor unit connected to the remote control switches.
- The control timer cannot be used together with this remote control switch.

4 SWITCH NAMES AND FUNCTIONS

The figure below shows all the indications for reference. The actual display during operation is different.



i] NOTE

- Do NOT press the switches hard or press with sharply pointed material such as a ball point pen. The operation part of the remote control switch may be damaged.
- Make sure that the switches are pressed softly with fingers.

5 TEST RUN

(1) Turn ON the power supply for all the indoor units.

(2) For the models with the auto-address function, wait for 3 minutes approximately. The addressing is automatically performed. (There is a case that 5 minutes is required according to the setting condition.) After that, select using language from "Menu". Refer to the operation manual for details.

(3) Press and hold "☵" (menu) and "⊃" (return) simultaneously for at least 3 seconds.

- a. The test run menu will be displayed.
- **b.** Select "Test Run" and press "OK". The test run settings will be displayed.

i NOTE

When "00" is indicated, the auto-address function may be performing. Cancel "Test Run" mode and set it again.

(4) The total number of the indoor units connected is indicated on the LCD (liquid crystal display). The case of the twin combination (one (1) set with two (2) indoor units) is indicated "2 units", and the triple combination (one (1) set with three (3) indoor units) is indicated "3 units".

- **a.** If the indicated number is not equal to the actual connected number of indoor unit, the auto-address function is not performed correctly due to incorrect wiring, the electric noise or etc. Turn OFF the power supply and correct the wiring after checking the following points; (Do not repeat turning ON and OFF within 10 seconds.)
- Power supply for indoor unit is not turned ON or incorrect wiring.
- Incorrect connectionn of connecting cable between indoor u nits or incorrect connection of controller cable.
- Incorrect setting of rotary switch and dip switch (the setting is overlapped) on the indoor units PCB.
- **b.** Press "U" (run/stop) to start the test run.
- **c.** Press " $\Delta \nabla \triangleleft \triangleright$ " and set each item.

5

Test Run: 2	units			
MODE	:		COOL	
SPEED	:	◄	HIGH	\blacktriangleright
LOUV.	:		N.	
T-RUN TIM	IE : 12	OMIN		
SEL. DAD	J Č	STO	D	

(5) Press "O" (run/stop). Start the test run when indicatin the air flow volume "HIGH" (default setting) and light the operation lamp. At this time, 2-hour OFF timmer will be set automatically..

Test Run	▲
Function Selection	01
Thermistor Selection	1
Input/Output	03
[⊠] Function 5]▼
SEL. OK ENT. SR	TN.
[
Test Run Setting: 2 units	_
MODE : < COOL >	
SPEED : MED	
SEL. (DADJ (DRUN SR	ΓN.
To at Dura Dattin an 00 unit	
SPEED : MED	
	_
SEL. 🖸 ADJ 🔱 RUN 🕤 RT	ΓN.
Toot Dup Sotting: 2 units	
Test run setting. Z units	_

MED

() RUN SRTN

Test run screen

Test Run Menu

SPEED

SEL. DADJ

(6) Press " Δ " or " ∇ ", select "LOUV." and select " \clubsuit " (auto swing) by pressing " \triangleleft " or " \triangleright ". The auto swing operation will be started. Check the operating sound at the louvers. If abnormal sound is not generated, press " \triangleleft " or " \triangleright " again to stop the auto swing operation.

Test Run: 2 MODE	units :	C00I
SPEED	:	HIGH
LOUV.	:	N
T-RUN TIM	1E:120	DMIN 💻 🔤
SEL. AD	n Q	STOP

(7) The temperature detections by the thermistors are invalid though the protection devices are valid during the test run.

(8) For SET-FREE Series: According to the label "Checking of Outdoor Unit by 7-Segment Display on PCB1" attached to the rear side of the front cover of the outdoor unit, check temperature, pressure and the operation frequency, and connected indoor unit numbers by 7-segment displays.

(9) To finish the test run, press " \bigcirc " (run/stop) again or pass over the set test run time. When changing the test run time, press " \triangle " or " ∇ " to select "T-RUN TIME". Then, set the test run time (30 to 600 minutes) by pressing " \triangleleft " or " \triangleright "

The RUN indicator on the remote control switch flashes when some abnormalities such as protection devices activated occur during the test run as well as the RUN indicator (orange) on the indoor unit flashes (0.5 second ON/ 0.5 second OFF). Additionally, the alarm code, the unit model code and connected number of indoor units will be displayed on the LCD as shown in the figure below. If the RUN indicator on PC-ARF flashes (2 seconds ON/ 2 seconds OFF), it may be a failure in the transmission between the indoor unit and the remote control switch (loosening of connector, disconnecting wiring or breaking wire, etc.). In this case, check the item 8.3 "Alarm Code" and perform for troubleshooting. Consult to authorized service engineers if abnormality can not be recovered.





ENGLISH

6 FUNCTION SELECTION AND SETTING

Function Selection and Input/Output



To set other units, press " \subseteq " (return) at (4)(5) so that the screen will return to (3). (If the number of indoor unit connected with the remote control switch is 1 (one), the screen will return to (1).)

◆ Table A Optional Setting Items for Function Selection

Items	Optional Function	Individual setting	Setting condition	Contents	
b1	Cancellation of heating temperature compensa- tion due to uneven heat load	0	00 01 02	Standard +4°C Removal (offset elimination) Set temperature +2°C (*1)	
b2	Circulator function at heating Thermo-OFF	0	00 01	Not available Available	
b3	Enforced 3 Minutes minimum operation time of compressor	0	00 01	Not available Available	
b4	Change of filter cleaning time	0	00 01 02 03 04	Standard 100 hrs 1,200 hrs 2,500 hrs No indication	
b5	Fixing of operation mode	×	00 01	Standard Fixed	
b6	Fixing of setting temperature	×	00 01	Standard Fixed	
b7	Fixing of operation as exclusive cooling unit	×	00 01	Standard Fixed	
b8	Automatic COOL/HEAT operation	×	00 01	Not available Available	
b9	Fixing of fan speed	×	00 01	Standard Fixed	
bA	Not prepared	×	-	Not used	
bb	Cooling temperature compensation due to uneven heat load	×	00 01 02	Standard (No Compensation) Set Temp. –1°C Set Temp. –2°C	
bC	Not prepared	-	-	Not used (Use as 00 conditions)	
bd	Not prepared	-	-	Not used (Use as 00 conditions)	
bE	Not prepared	-	-	Not used (Use as 00 conditions)	
C1	Not prepared	-	-	Not used (Use as 00 conditions)	
C2	Not prepared	-	-	Not used	
C3	HA function (only for Japanese market)	0	00 01	Not available (Use as 00 conditions) Available	
C4	Drain Pump Operation at Heating	0	00 01	Not available Available	
C5	Hi speed (Except for Hi Speed at Heating Thermo-OFF)	0	00 01 02	Not available Hi Speed 1 (*2) Hi Speed 2	
C6	Hi speed at heating Thermo-OFF	0	00 01	Not available Available	
C7	Canceling of enforced 3 minutes minimum operation time of compressor	0	00 01	Standard Cancellation	
			00	Not available	
C8	Thermistor of remote control switch	0	01	Control by thermistor of remote control switch	
			02	Control by average value of indoor suction ther- mistor and thermistor of remote control switch	
C9	Not prepared	-	-	Not used	
CA	Not prepared	-	-	Not used	
Cb	Selection of forced stoppage logic	×	00 01	Forced stoppage input: A Contact Forced stoppage input: B Contact	
CC	Not prepared	×	-	Not used (Use as 00 conditions)	
Cd	Not prepared	-	-	Not used (Use as 00 conditions)	
CE	Not prepared	-	-	Not used (Use as 00 conditions)	
			00	Standard (7-Step Operation)	
CF	Change of louver swing angle	0	01	Cold draft prevention (5 Steps: lower 2 steps cut off)	
			02	High ceiling (5 Steps: upper 2 steps cut off)	

Items	Optional Function	Individual setting	Setting condition	Cont	ents
d1	Power supply ON/OFF 1	0	00 01	Not available Available	
d2	Not prepared	-	-	Not used	
d3	Power supply ON/OFF 2	0	00 01	Not available Available	
d4	Prevention for cooling discharge air temperature decrease	0	00 01	Not available Available	
d5	Prevention for heating discharge air temperature decrease	0	00 01	Not available Available	
d6	Room temperature control for energy saving	0	00 01	Not available Available	
d7	Fall distance of elevating panel (Indoor units with the elevating grille function only)	0	00 01 02 03 04 05 06 07	200 cm (Standard) 100 cm 150 cm 200 cm 250 cm 300 cm 350 cm 400 cm	
			00	Automatic ventilation	This function is used
	KPI: Ventilation mode		01	Ventilation by total heat exchanger	to set the ventilation mode of the ventilation
E1		0	02	Ventilation with bypass (no total heat exchanger)	unit with energy / heat recovery.
			00	Not available	This function allows
	Econofresh: cooling mode		01/02	Outdoor cooling mode (all-fresh)	for the outdoor air damper to be opened.
		0	00	Not available	This function is used
E2	KPI: Increased air supply volume		01	Available	supply pressure in the room.
			00	Not available	This function selects
	Econofresh: enthalpy sensor		01	Available	input.
			00	Not Used	
E3	Not used	0	01	Used as setting for conditions 00	-
			KPI:		
			00	Standard	
			01	30 minutes	This function delays
E4	Pre-cooling / Pre-heating period	0	02	60 minutes	tion unit with energy /
			Econofresh kit:		heat recovery
			00	Standard	
55	Not proported		01/02	CO_2 sensor	nditiona)
ED	Not prepared	*	-	Not used (Use as 00 co	nullions)
E6	Indoor fan operation time after cooling operation stoppage	0	01 02	60 min. 120 min.	
E7	Not prepared	0	-	Not used (Use as 00 co	nditions)
E8	Fan operation control at heating Thermo-OFF	0	00 01	Not available SLOW	
E9	Not prepared	-	-	Not used (Use as 00 co	nditions)
EA	Not prepared	-	-	Not used (Use as 00 co	nditions)
Eb	Fan operation control at cooling Thermo-OFF	0	00 01 02	Not available LOW SLOW	
EC	Forced Thermo-ON stoppage at cooling	0	00 01	Not available Available	
Ed	Not prepared	-	-	Not used (Use as 00 co	nditions)

Items	Optional Function	Individual setting	Setting condition	Contents
EE	Automatic fan speed control	0	00	Not available Available
F0	Not prepared	-	-	Not used
F1	Automatic OFF timer setting * Do not set the functions "0C"~"0F" when 2 (two) remote control switches are used in the same remote control group.	×	00 01 02 • 23 24 0A 0B 0C 0D 0C 0D 0E 0F	No function OFF Timer by 1 hr OFF Timer by 2 hrs • • OFF Timer by 23 hrs OFF Timer by 24 hrs OFF Timer by 24 hrs OFF Timer by 30 min. OFF Timer by 90 min. OFF Timer by 90 min. OFF Timer by 40 min. OFF Timer by 45 min. OFF Timer by 50 min. OFF Timer by 55 min.
F2	Remote control main-sub setting	×	00 01	Main Sub
F3	Automatic reset of setting temperature (*4)	×	00 01 (*10)	Not available Available
F4	Automatic reset time	×	00 01 02 (*10) 03	30 min. 15 min. 60 min. 90 min.
F5	Automatic reset temperature for cooling (*5)	×	19 20 • 25 • 29 30	19°C 20°C • • 25°C (Factory setting) • • 29°C 30°C
F6	Automatic reset temperature for heating (*6)	×	17 18 • 21 • 29 30	17°C 18°C • • 21°C (Factory setting) • • 29°C 30°C
F7	Operation stoppage prevention by remote control switch operational error (*7)	×	00 01	Not available Available
F8	Lock function for operation mode selection	×	00 01	Not available Available (Factory setting)
F9	Lock function for temperature setting	×	00 01	Not available Available (Factory setting)
FA	Lock function for fan speed selection	×	00 01	Not available Available (Factory setting)
Fb	Lock function for swing louver operation	×	00 01	Not available Available (Factory setting)
FC	Cooling lower limit for setting temperature (*5)	×	00 01 02 • • 09 10	Standard Lower limit +1°C Lower limit +2°C • • Lower Limit +9°C Lower Limit +10°C
Fd	Heating upper limit for setting temperature (*6)	×	00 01 02 • 11 12	Standard Upper limit –1°C Upper limit –2°C • • Upper limit –11°C Upper limit –12°C

ENGLISH

ltems	Optional Function	Individual setting	Setting condition	Contents
FE	Not prepared	-	-	Not used (Use as 00 conditions)
FF	Not prepared	-	-	Not used (Use as 00 conditions)
H1	Not prepared	-	-	Not used (Use as 00 conditions)
H2	Indication of hot start	×	00 01	Indication No indication
H3	Not prepared	-	-	Not used (Use as 00 conditions)
H4	Not prepared	-	-	Not used (Use as 00 conditions)
J1	Temperature indication (*8)	×	00 01	Not available Available
J2	Not prepared	-	-	Not Used
J3	Run indicator color	×	00 01	Green Red
J4	Not prepared	-	-	Not used (Use as 00 conditions)
J5	Not prepared	×	-	Not used (Use as 00 conditions)
J6	Error sound	×	00 01	Once Sequence
J7	Not prepared	-	-	Not Used (Use as 00 conditions)
J8	Eco-operation (*9)	×	00 01 (*10)	Not available Available
J9	Not prepared	-	-	Not used (Use as 00 conditions)
JA	Not prepared	-	-	Not used (Use as 00 conditions)
Jb	Not prepared	-	-	Not used (Use as 00 conditions)
K1	Not prepared	×	-	Not used
K2	Not prepared	×	-	Not used
K3	Not prepared	×	-	Not used
K4	Not prepared	-	-	Not used
K5	Human sensor detection level (*11)	-	00 01 02	Standard High

*1: The "02" setting may not be available according to the type of indoor unit.

*2: In case of RPI models, 00: standard, 01: high static pressure, 02: low static pressure

*3: E1 to E4: Setting for the total heat exchanger.

*4: In case that the set temperature is changed and kept within the set time at "F4", the temperature is automatically changed to "F5" and "F6". (In case that the set temperature is out of range at "F5" and "F6", it is applied within upper and lower limit for the set temperature.)

*5: Applicable to fan, cooling and dry operation modes.

*6: Applicable to heating operation mode.

*7: Operation is stopped by pressing the "" (run/stop) switch for 3 seconds.

*8: The sensor value at "C8" will be indicated. When the thermistor for remote control switch is used, the average value of the thermistor for remote control switch and the thermistor for indoor inlet will be indicated. *9: When the unit is restarted by the remote control switch, the temperature automatically changes to the setting temperature of "F5" or "F6".

*10: If function F2 is set up 01 (Sub) is displayed "--".

*11 This function is for air panel with motion sensor. If the air panel don't have available the motion sensor, setting condition is displayed as "--".



- After at least 3 minutes from the power ON, change the optional setting.
- When changing "CF" setting (change of louver swing range), restore the power supply or allow the louver to make one complete swing fully in the auto swing mode to apply the optional setting.
- The optional settings are different according to the indoor and outdoor unit models. Check to ensure that the unit has the optional setting or not.
- Record the setting conditions for each optional setting in the "Setting" column of the table.

◆ Table B Input and Output Number Display and Connectors

Input number display	Dout	Factory setting		
Input/Output indication	Port	Setting item	Indication	
Input 1	CN3 1-2	Remote ON/OFF 1 (Level)	03	
Input 2	CN3 2-3	Prohibiting Remote Control after Manual Stoppage	06	
Output 1	CN7 1-2	Operation	01	
Output 2	CN7 1-3	Alarm	02	
Output 3	CN8 1-2	Thermo-ON for Heating	06	

◆ Table C Input and Output Settings and Display Codes

Indication	Input	Output
00	Not set	Not set
01	Room Thermostat (for Cooling)	Operation
02	Room Thermostat (for Heating)	Alarm
03	Remote ON/OFF 1 (Level)	Cooling
04	Remote ON/OFF 2 (Operation)	Thermo-ON for Cooling
05	Remote ON/OFF 2 (Stoppage)	Heating
06	Forbidding Remote Control after Manual Stoppage	Thermo-ON for Heating
07	Remote Cooling / Heating Change	Total Heat Exchanger
08	Elevating Grille Input	Elevating Grille Output

i note

- After at least 3 minutes from the power ON, change the optional setting.
- The elevating grille input can be set to "Input 2" only.
- The elevating grille cannot be set to "Input 1".
- The elevating grille output can be set to "Output 1" or "Output 2" only.
- The elevating grille output cannot be set to "Output 3".
- Do not set the elevating grille for the total heat exchanger.
- · Record the setting conditions for each input and output in the "Setting" column of the table.

Thermistor Selection

This function changes the temperature thermistor from indoor unit thermistor to thermistor of remote control switch or an average between both temperatures.

(1) Press and hold " \equiv " (menu) and " \subseteq " (return) simultaneously for at least 3 seconds during the normal mode (when unit is not operated). The test run menu will be displayed.

(2) Select "Thermistor Selection" from the test run menu and press "OK".

Test Run Menu	
Test Run	
Function Selection	01
Thermistor Selection	1
Input/Output	03
^{III} Function 5	▼
SEL. OK ENT. SR	TN.

Thermistor Sele	ction	
Thermistor:	I.U. Thermistor	\blacktriangleright
ADJ	OK ENT.	RTN.

(3) Change the temperature thermistor item by pressing " $\lhd\!\!\!\!\!\triangleleft\!\!\!\!\!\!\triangleleft$ " and press "OK".



Test Run Menu

(4) Select "Yes" and press "OK". The test run menu will be displayed after the setting is confirmed. If "No" is pressed, the screen will return to (3).

(5) Press " \subseteq " (return) on the test run menu to return to the normal mode.

Indoor Unit Address Change

This function changes the address (refrigerant cycle number and indoor unit number) of indoor units. If this setting is done, it will take priority over DIP Switch setting.

(1) Press and hold "☴" (menu) and "与" (return) simultaneously for at least 3 seconds during the normal mode (when unit is not operated). The test run menu will be displayed.

(2) Select "I.U. Address Change" from the test run menu pressing " Δ ∇ " and "OK".

(3) Select the indoor unit by pressing " $\Delta \nabla \triangleleft \triangleright$ " and press "OK".

* Indoor units which are not supporting "I.U. Address Change" function can not be selected.

(4) Determine the new indoor unit address.

Press " $\Delta \nabla \triangleleft \triangleright$ " to switch the refrigerant cycle number and address in range of 00-63.

To display confirmation screen press "OK".

* "Cycle No.99" is used as a temporary address only when all the cycle numbers and unit numbers are in use (occupied).

If "Cycle No.99" is used temporarily, the address must be changed within the standard range of 00-63.

(5) The confirmation screen will be displayed. Select "Yes" and press "OK" to stard address change process. Result will be displayed in seconds. If "No" is pressed, the screen will go to (6).

*When the process successfully completes, "Completed" will be displayed.

Otherwise the porecess has been failed. Check the setting and contents again.

(6) To change the address for another indoor unit, select "I.U. Select" and press "OK". the screen will return to (3). To finish this function select "Completed" and press "OK".

*If "I.U. Address Change" is successfully completed, connection check will be started automatically.

13

(7) Turn OFF the power supply of the indoor units for 3-5 minuts. Wait until the remote control switchs display turn off, and turn ON the power supply of indoor units again.



SEL.	ADJ	OK ENT.	S RTN
.U. Add	lress Chang	e: 02-04	
	Change a from 02-0 Yes	ddress 4 to 02-05? No	
SEL.		OK ENT.	S RTN.

I.U. Address Change: 02-05

I.U. Select

SEL.

Completed.

Completed

OK ENT.

i NOTE

- "I.U. Address Change" is not available when the control of 2 remote control switches (main and sub) are used.
- Do not operate from the central controlling devices while "I.U. Address Change" is performed by the remote control switch.
- This function should not be used if there is a Central Control (like CSNET WEB) in the H-LINK line.

Address Check Operation

This function is used to check the relation between the indoor unit and I.U. address. This operation is effective when multiple indoor units are connected to the remote control switch and address of the certain unit is unknown.

(1) Press and hold " Ξ " (menu) and " \Box " (return) simultaneously for at least 3 seconds during the normal mode (when unit is not operated). The test run menu will be displayed.

(2) Select "ADD Check Operation" from the test run menu pressing " Δ ∇ " and "OK".

(3) Select the indoor unit by pressing " $\Delta \nabla \triangleleft \triangleright$ ".

(4) Tostartoperation of the indoor unit selected in (3) press "" (run/stop). To return to (3) screen press "" (run/stop) while indoor units is operated.

*Repeat (3)-(4) until desired indoor unit address is confirmed.

I.U. ADD Check Operation						
01-01	02-01	03-01	04-01			
01-02	02-02	03-02	04-02			
01-03	02-03	03-03	04-03			
01-04	02-04	03-04	04-04			

(5) To return to the test run menu press "S" (return) while indoor unit is not operated.

Confirm the selected indoor unit address and go to "I.U. Address Change".

ί ΝΟΤΕ

- "ADD Check Operation" is not available when the control of 2 remote control switches (main and sub) are used.
- The switch operation other than "Run/Stop" is not available while "ADD Check Operation" is performed.
- Do not operate from the central controlling devices while "ADD Check Operation" is performed by the remote control switch.
- This function should not be used if there is a Central Control (like CSNET WEB) in the H-LINK line.

Indoor Unit Address Initialization

Thisfunctioninitializes the indoor unit address that has been changed by "I.U.Address Change" function or set by the automatic address allocation. Initializing the address by this function, indoor unit address will be changed to the dip switch setting.

(1) Press and hold " \equiv " (menu) and " \subseteq " (return) simultaneously for at least 3 seconds during the normal mode (when unit is not operated). The test run menu will be displayed.

(2) Select "I.U. ADD Initialization" from the test run menu pressing " Δ ∇ " and "OK".

(3) Select the indoor unit by pressing " $\Delta \nabla \triangleleft \triangleright$ " and press "OK". The confirmation screen will be displayed.

*Indoor unnits which are not supporting "I.U. ADD Initialization" function can not be selected.

The address of indoor unit that does not support "I.U. ADD Initialization" function will not be initialized even when "All" is specificated at (3).

Test Run Menu	
I.U. Address Change	
ADD Check Operation	02
I.U. ADD Initialization	1
FUNC, Input/Output INITIAL.	03
^{III} Function 10	▼
SEL. OK ENT. SR	TN.

I.U. ADD Initialization						
	А	JI				
01-01	02-01	03-01	04-01			
01-02	02-02	03-02	04-02			
01-03	02-03	03-03	04-03			
01-04	02-04	03-04	04-04			
♦SEL. 🕐 RUN 🕤 RTN.						

(4) Select "Yes" and press "OK" to start the address initialization process.

*If the address initialization is successfully completed, connection check will be started automatically.

Function Selection and Input/Output Initialization

This function re-establishes the function selection and Input/Output values to factory setting values.

(1) Press and hold "Ξ" (menu) and "⊃" (return) simultaneously for at least 3 seconds during the normal mode (when unit is not operated). The test run menu will be displayed.

(2) Select "FUNC, Input/Output INITIAL" from the test run menu pressing " $\Delta \nabla$ " and "OK".

(3) Select the indoor unit by pressing " $\Delta \nabla \lhd \triangleright$ " and press "OK".

*This screen is not displayed when the number of indoor units connected with the remote control switch is 1 (one). In this case, (4) will be displayed.

(4) To start initialization, select "Yes" and press "OK" on the confirmation screen. It thakes approx. 30 seconds to complete the process.

*Check that initialization will not cause any problems, and then start the initialization work.

(5) Select "Completed" and press "OK". The test run menu will be displayed.

Press "与" (return) on the test run menu to return to the normal mode.

To initialize setting for the other indoor units, select "I.U. Select" and press "OK". The screen will return to (3).

15

NOTE

- "No Function" will be indicated when the indoor unit that does not support the initialization function for "Function Selection" and "Input/Output Setting".
- The setting for indoor units that does not support the initialization function for "Function Selection" and "Input/Output Setting" will not be initialized even when "All" is specified at item (3).

Test Run M					
	dross Ch	ando			
1.0. Address Change					
1.U. AD	D Initializ	ation	/		
FUNC,	Input/Ou	tput INI I	AL. 03		
Functio	n 10		▼		
SEL.		OK ENT.	S RTN.		
FUNC, In	put/Output	INITIAL.			
	A	.11			
01-01	02-01	03-01	04-01		
01-02	02-02	03-02	04-02		
01-03	02-03	03-03	04-03		
01-04	02-04	03-04	04-04		
SEL.		り RUN	S RTN.		
FUNC, In	put/Outpu	t INITIAL.	: 02-04		
Restore factory default settings for funtion selection - input/output?					
SEL.		OK ENT.	S RTN.		
FUNC, Inj	 out/Output	OK ENT.	02-04		
FUNC, In	put/Output Compl	OK ENT.	02-04		
FUNC, Inj	put/Output Compl J. Select	OK ENT. INITIAL.: eted. Comple	02-04		

HITACH



Compressor Preheating Cancellation

This function cancells the compressor preheating control.

(1) Press and hold "☴" (menu) and "与" (return) simultaneously for at least 3 seconds during the normal mode (when unit is not operated). The test run menu will be displayed.

(2) Select "COMP Preheating CANC" from the test run menu pressing " Δ ∇ " and "OK".

(4) The confirmation screen will be displayed.

(5) Select "Yes" and press "OK". The test run menu will be displayed after the setting is confirmed. If "No" is pressed, the screen will return to test run menu.

(6) Press " $\!$ (return) on the test run menu to return to the normal mode.

Test Run Menu	
COMP Preheating CANC	
Contact Information	03
	1
	03
	▼
	TN.
COMP. Preheating Control CANC	
Cancel preheating control for compressor?	
Yes No	
	TN.

7 ELEVATING GRILLE SETTING/CANCELLATION

This function is available to set the elevating grille setting/cancellation for the all connected indoor units with the elevating grille function. It is set to the external input 2, external output 1 and 2 as following procedure.

• Elevating Grille Setting/Cancellation Procedure

(1) Press and hold "\≡" (menu) and "≤" (return) simultaneously for at least 3 seconds during the normal mode (when unit is not operated). The test run menu will be displayed.

(2) Select "Input/Output" from the test run menu and press "OK".

(3) Select the indoor unit by pressing " $\Delta \nabla \triangleleft \triangleright$ " and press "OK". (This screen is NOT displayed when the number of indoor unit connected with the remote control switch is 1 (one). In this case, (4) will be displayed.)



i NOTE

- In case of using by two remote control switches (Main and Sub), the settings shall be operated by the main remote control switch.
- If "All" is selected at (3), this setting is set to all the indoor units connected to the remote control switch regardless of the actual elevating grille.
- Please note that when functions other than the elevating grille have been set for input 2 and output 1 and 2, those settings are cleared (Namely, the elevating grille function will be overwritten).

8 LOUVER SETTING

This setting is available only for the indoor unit adopting the individual louver.

The each louver angle can be set individually as following procedure.

(1) Press "≔" (menu) during the normal mode (when unit is operated). The menu will be displayed.

(2) Select "Louver Setting" from the menu and press "OK". The louver setting will be displayed.

(3) Select "Louver Setting" from the louver setting and press "OK".

(4) Select the indoor unit to change the louver direction by pressing " $\Delta \nabla \triangleleft \triangleright$ " and press "OK".

(This screen is NOT displayed when the number of indoor unit connected with the remote control switch is 1 (one). In this case, (5) will be displayed).

(5) Press " $\triangleleft \triangleright$ " and select the louver direction. The selected louver is opened and the other louvers are closed.

(6) Press "Ξ" (menu) while "?" (help) is pressed. The confirmation screen will be displayed.

(7) Select "Yes" and press "OK". (5) will be displayed after the setting change is confirmed. If "No" is selected and "OK" is pressed, the screen will return to (5).

* Regarding "Louver Setting", the louver selected at (5) will be set as "N°1" and the other louver N° will be changed clockwise automatically as shown in the figure.

i NOTE

This "Louver Setting" is NOT available when the 2 (two) remote control switches are used in the same H-LINK. (including combination with PC-ARF + PC-LH3A (Wireless Remote Control Switch)).



Louver Setting
Louver Setting
Cancel INDV Louver SET
SEL. OK ENT. SRTN.

Louver S	etting
01-01	
01-02	
01-03	
01-04	
	Select unit to set.
SEL.	ok ent. Srtn.





9 CONTACT INFORMATION REGISTRATION

Contact information can be registered from "Contact Information".

(1) Press and hold "\\equiv (menu) and "\sigma" (return) simultaneously for at least 3 seconds during the normal mode (when unit is not operated). The test run menu will be displayed.

- (2) Select "Contact Information" from the test run menu and press "OK". The contact information 1 will be displayed.
- (3) Press "?" (help) to change font type.
- (4) Press " $\Delta \nabla \lhd \triangleright$ " to select letter.
- (5) Press "OK" to confirm the letter. (Max.: 28 letters)
- (6) Select "FIN." and press "OK" (or simply press "Ξ" (menu)),
- (7) will be displayed.

Contact Information 1												
ABC		,	+	*	;		?	-	1	:	=	Π
abc		1	2	3	4	5	6	7	8	9	0	
Sym.1	4	q	w	е	r	t	У	u	i	0	р	
Sym.2	Ν	€	а	s	d	f	g	h	j	k	Ι	14
		<	>	z	х	с	v	b	n	m	,	
		SP	AC	D	EL	←	\rightarrow		FI	N.		
SEL.	1) [ette	r			OK	EN	Т.	1	FI	N.

(7) Repeat (3)~(5) to register contact information 2.

Select "FIN." and press "OK", the confirmation screen will be displayed. (Also, press " Ξ " (menu) and the confirmation screen will be displayed).

(8) Select "Yes" and press "OK". The test run menu will be displayed after the setting is confirmed. If "No" is pressed, the screen will return to (3).



10 CHECK MENU

Each "Check Menu" item and its function are explained in the following table.

Check menu item	Function
Check 1	Sensor condition of air conditioner will be monitored and indicated.
Check 2	Sensor data of air conditioner prior to alarm occurrence will be indicated.
Alarm history display [⊤]	Previous alarm record (date, time, alarm code) will be indicated.
Model display	Model name and manufacturing number will be indicated.
IU/OU PCB check	The result of PCB check will indicated.
Self checking	Checking of remote control switch will be carried out

Indication of Check Menu



simultaneously for 3 seconds during the normal mode.

T: To Erase Alarm History.

Press "OK" when the abnormality record is indicated. After that, the confirmation screen will be displayed.

Select "Yes" and press "OK" so that the alarm record will be deleted.

11 OPERATION METHOD

11.1 BASIC OPERATION

1 Item Selection.

By pressing "√" or "▷", the icon "⊡" will move to the next item in order of the indications "MODE", "SPEED", "LOUV." and "TEMP".



2 Change of Settings

With the item ("MODE", "SPEED", "LOUV" or "TEMP") selected, press " Δ " or " ∇ ". The setting will be changed.



11.2 OPERATION MODE (COOLING, HEATING, DRY, COOLING/HEATING AUTOMATIC AND AIR FLOW OPERATION)

- ♦ Function
- Cooling Operation (COOL):
- To decrease the room temperature.
- Heating Operation (HEAT):
- To increase the room temperature.
- Dry Operation (DRY):

To decrease the humidity in the room.

- Cooling/Heating Automatic Operation (AUTO):
- To cooling and heating automatic changeover.
- Air Flow Operation (FAN):

To circulate the air in the room.

i NOTE

The available set temperature is as follows:

- Cooling Operation: 19 to 30°C
- Heating Operation: 17 to 30°C
- Dry Operation: 19 to 30°C

Before Operation

\triangle caution

- Supply the electrical power to the system for approximately 12 hours before start-up after long shutdown. Do not start the system immediately after the power supply, it may cause a compressor failure, because the compressor is not heated well. Do NOT turn OFF the power supply during the seasons.
- Make sure that the outdoor unit is not covered with snow or ice. If covered, remove it by using hot water (less than 50°C).
- If the water temperature is higher than 50°C, it will cause damage to plastic parts.



2 Press "⊲" or "▷" and select "MODE".



3 By pressing " Δ " or " ∇ ", the operation mode will be changed as follows.





i) NOTE

The advanced setting is required for the "AUTO" operation. Contact your distributor or dealer of HITACHI for detailed information.

S F

IDNE

12 SETTING METHOD

12.1 TEMPERATURE SETTING

1 Press "⊲" or "▷" and select "TEMP".





2 By pressing "∆", the temperature is increased by 1°C. (Max. 30°C). By pressing "∇", the temperature is decreased by 1°C. (Cooling, Dry, Air Flow operation: Min. 19°C) (Heating operation: Min. 17°C).





TEMF

12.2 FAN SPEED

1 Press "⊲" or "▷" and select "SPEED".



2 By pressing " Δ " or " ∇ ", the fan speed will be changed as follows.





The max/min temperature is available to change by setting the cooling lower limit for setting temperature (or heating upper limit for setting temperature) from the function selection.



- During the dry operation, the fan speed is automatically changed to "LOW" and cannot be changed to other fan speed. ("LOW" will NOT be displayed on LCD (liquid crystal display) at this time. The present setting condition will be displayed on LCD).
- The fan speed settings "HIGH H" and (or) "AUTO" may not be available depending on the indoor unit type.

1 Press "⁽U)" (run/stop). Make sure that the operation is started. Press "[⊲]" or "[▷]" and select "LOUV".



LCD Indication



i note

For the indoor unit without the auto louver mechanism, the indication of "LOUV." will NOT be displayed on LCD.

2 By pressing " Δ " or " ∇ ", the louver direction will be changed as follows.

Angle range

COOL, DRY HEAT, FAN

Auto-swina

Angle range

mended

13 OPERATION

13.1 OPERATION START

Press " \bigcirc " (run/stop). The run indicator will be turned on and the operation will be started.



·Δ

- 스







- The air flow angle is different for each indoor unit type. Check Installation & Operation Manual for Indoor Unit to be used for the detailed information.
- Louver position on LCD and the actual louver position may not match during the auto swing operation. To fix the louver positions, set the angle after checking the position on LCD.
- The louver may NOT stop immediately right after the switch is pressed.



- Temperature/Air Flow Setting
- The setting condition will be memorized once after the setting is confirmed, therefore the daily setting is not required. In case that the setting change is required, refer to the Operation Method and Setting Method chapters.

13.2 OPERATION STOP

Press " $\overset{(l)}{\bigcup}$ (run/stop) again. The run indicator will be turned off and the operation will be stopped.



13.3 OPERATION LOCK

- This function is used to lock the setting from the remote control switch.
- The following functions are applicable.
 - a. Operation Mode (MODE)
 - b. Temperature Setting (TEMP)
 - c. Fan Speed (SPEED)
 - d. Swing Louver Direction (LOUV)
- Setting of the operation lock, press "▷" and "⊃" (return) simultaneously for 3 seconds. The icon of "□" will be turned ON. Even when "<" or "▷" is pressed, locked setting items will be skipped.</p>



14 MENU OPERATION

14.1 MENU

Every setting function is displayed in the menu. Refer to the following sections for each function.



: Unable to set .

If the function with " \boxtimes " is selected from the menu, "No Function" or "Setting Disabled" will be displayed on the lower screen.

1 Press ": (menu). The menu will be displayed.



2 Select the function by pressing " Δ " or " ∇ " and press "OK".

PMML0225A rev.2 - 12/2012 - P5414866

(" \boxtimes " will be displayed if the function is not available).

23



Menu	15:10(F	ri)
Filter Sign Reset		
Elevating Grille		01
Eunction 3		/
Simple Timer		03
Schedule Timer		•
SEL. OK	ent. 🕤 R	TN.

3 Press "≦" (return) to return to the normal mode (Operation Mode Indication).



A/C Meeting Room		
MODE SPEED	TEMP	
COOL 😽 HIGH	28	
SPEED 🖨 ADJ		



If the menu screen remains unchanged for approximately 10 minutes, the screen will automatically return to the normal mode.



After the heating operation is stopped, the air flow operation may be activated for approximately 2 minutes.

2 Cancellation of the operation lock, press "▷" and "≦" (return) simultaneously for 3 seconds. " If will be turned OFF, and operation lock will be canceled.





- Every time pressing ⁽▷" and "⁽⊃" (return) simultaneously for 3 seconds, the operation lock state will be switched alternately to locked/unlocked.
- Select the functions to lock at the function selection setting. Contact your distributor or dealer of HITACHI for detailed information.

14.2 FILTER SIGN RESET

This function is used to turn off the filter sign indication.



If the function with the indication of " \boxtimes " is selected from the menu, "Setting Disabled" will be displayed because the setting accumulated time by function b4 is insufficient.

1 Select "Filter Sign Reset" from the menu and press "OK". The confirmation screen will be displayed.



14.3 ELEVATING GRILLE

This function is available only when the elevating grille is equipped with the air panel.

\triangle caution

Caution of Setting Elevating Grille into Air Panel After Cleaning.

When the air inlet grille is set inside the air panel, ensure that the air inlet grille is horizontal and the wire is suspended tightly without loosening. After the above is ensured, set the air inlet grille. If the air inlet grille is inclined and the wire is loosened, they may be caught in the pulley. It may lead to a failure of the pulley or pulley block. If the worst happens, it may cause personal injury due to falling the air panel.



This function is for the air inlet grille automatically moves upward or downward from the air panel when cleaning the air filter and air inlet grille. 2 Select "Yes" by pressing "< " or "▷" and press "OK". The indication of "FLTR" will be turned OFF and the screen will return to the normal mode.



i) _{NOTE}

- This function is available only when the elevating grille is equipped with the indoor unit.
- Make sure that the unit operation is stopped before using the elevating grille.
- The elevating grille function is not available when the unit is operated.
- 1 Press "≔" (menu) and select "Elevating Grille" from the menu. Press "OK".



If the number of indoor unit connected with the remote control switch is 1 (one), (3) will be displayed after the procedure (1).

 Select the indoor unit by pressing "∆", "∇", "<I" or "▷". Press "OK".

Elevating	Grille	UPDW
	All	
00-00		
01-01		
02-02		
SEL.	Oł	K ENT. 🕤 RTN.

- 3 Press " ∇ ". The elevating grille starts lowering.
- Once "∇" is pressed, the elevating grille lowers to the specified height.
- If "∇" is pressed once again, the elevating grille lowers by 50cm from the present height. (When "∇" is pressed each time, the elevating grille lowers respectively by 50cm.)
- To stop the elevating grille, press " Δ ".



4 When the cleaning is finished, press "∆". The elevating grille starts rising. The grille will be set inside the air panel and stopped moving after 3 seconds. (If the air inlet grille is inclined at this time, press "∆" again. An inclination may be corrected).



14.4 SIMPLE TIMER OPERATION

This function is used to start or stop the unit operation at the setting time.

The timer operation contents can be set from "Once" or "Everyday".

1 Select "Simple Timer" from the menu and press "OK". The simple timer setting will be displayed.



i NOTE

If the present time has not been set yet, automatically "Set Date/ Time" will be displayed. Refer to Adjusting Date/Time section.

2 Press "∆" or "∇" to select the setting items. The setting items are displayed "Timer Ope.", "ON Time" and "OFF Time".



5 Press "≦" (return). The screen will return to (2). If necessary, set the elevating grille for other indoor units). To finish the setting, press "≦" (return) again. The screen will return to the menu. If "≦" (return) is pressed once again, the screen will return to the normal mode.



If the number of indoor unit connected with the remote control switch is 1 (one), the screen will return to the normal mode after "rightarrow" (return) is pressed.

3 Press "⊲" or "▷" to set each setting content for the selected item. When "Timer Ope." is selected, the setting contents are switched in order of "Not Used" ↔ "Once" ↔ "Everyday" by repeatedly pressing "⊲" or "▷". When "ON Time" or "OFF Time" is selected, the setting time can be set every 30 minutes by pressing "⊲" or "▷". Press and hold "⊲" or "▷", the setting time can be continuously indicated.



Ι ΝΟΤΕ

If "Once" of the timer operation setting is selected, the setting content will be automatically changed to "Not Used" after "Once" timer operation.

4 Press "OK" to finish the simple timer setting. The confirmation screen will be displayed.



5 Select "Yes" by pressing "⊲" or "▷" and press "OK". The setting will be confirmed and the screen will return to the normal mode.





" \bigcirc " will be indicated when the timer operation is activated.

14.5 SCHEDULED OPERATION

14.5.1 Schedule setting

This function is used to start or stop the unit operation at the setting time.

Temperature can be also set when the unit is operated.

Five different schedule timers (max.) can be set for each day of the week.

1 Select "Schedule Timer" from the menu and press "OK".



2 Select "Day/Time Setting" by pressing " Δ " or " ∇ " and press "OK".





If the present time has not been set yet, automatically "Set Date/ Time" will be displayed. Refer to Adjusting Date/Time.

- Select the day of the week (from Monday to Sunday) by pressing "∆" or "∇". Press "OK".
- "■" (run) and "□" (stop) will be displayed on LCD.
- To copy the setting contents of the previous day, press "⊲" and "OK" simultaneously.

i NOTE

In the case of the following condition, the simple timer operation is NOT available:

- When the prohibiting operation by remote control switch is set from the central controller.
- When "">
 ⁽¹⁾ is indicated on LCD, the timer operation cannot perform. Set the date and time according to Adjusting Date/ Time section.

Example:

The setting contents of Monday is copied in Tuesday.

- a. Select "Tue".
- **b.** Press "⊲" and "OK" simultaneously.
- c. The setting contents of Monday are copied in Tuesday.



- 4 Select the schedule No (from 1 to 5) by pressing "△" or "∇ ". Select "ON Time", "OFF Time" or "Setting Temperature" by pressing "⊲" or "▷". Set the ON/OFF timer and temperature by pressing "△" or "∇".
- Press or keep pressing " Δ " or " ∇ " to adjust numbers.
- Five different schedule timers (max) can be set for each day of the week.



Time	er Setting	(Mon	ı)	15:10(Fri)
1	08:30	~	12:15	28°C‡
2	:	~	:	°C
3	:	~	:	°C
4	:	~	:	°C
5		~	:	°C
SE SE	L. 🔂 ADJ		OK EN	IT. ち RTN.
L				

The figure shows that following timers are set for Monday;

ON Timer: 8:30

OFF Timer: 12:15

Setting Temperature: 28°C

ENGLISH

5 Press "OK". The confirmation screen will be displayed.



6 Select "Yes" by pressing "<]" or "▷" and press "OK". The setting will be confirmed and the screen will return to the normal mode. To set other days of the week, select "Set other day" and press "OK".





"(-)" will be indicated when the schedule operation is activated.

i) NOTE

In the case of the following condition, the schedule operation is NOT available;

- When the prohibiting operation by remote control switch is set from the central controller.
- When "">" is indicated on LCD, the schedule operation cannot perform. Set the date and time according to Adjusting Date/Time section.

14.5.2 Holiday setting

This function is used to deactivate the schedule operation temporarily.

This function is used to deactivate the schedule operation just for one day. After that, the schedule operation will recover automatically.

This function is used to set irregular schedules such as national holidays.

1 Select "Schedule Timer" from the menu and press "OK". The schedule timer setting will be displayed.



2 Select "Holiday Setting" by pressing " Δ " or " ∇ " and press "OK".



- Select the day of the week to stop the operation by pressing "∆" or "∇". Select "HOL. ON/OFF" by pressing "<" or "▷".
- "∎" and "□" will be changed to "■" and "⊡" on LCD.



4 Press "OK" after the setting is completed. The confirmation screen will be displayed.



5 Select "Yes" by pressing "< " or "▷" and press "OK". The holiday setting will be confirmed and the screen will return to the normal mode.







 $(\stackrel{(+)}{\rightarrow})$ " will be turned off when the holiday setting is activated.

14.5.3 Schedule ON/OFF setting

This function is used to deactivate the schedule operation temporarily.

The schedule operation will not be carried out when "OFF" is set in this function.

This function is used to apply for long period of holidays.

1 Select "Schedule Timer" from the menu and press "OK".



 Select "Schedule ON/OFF" by pressing "∆" or "∇" and press "OK". The confirmation screen will be displayed.



14.6 INDIVIDUAL LOUVER SETTING

14.6.1 Setting

This setting is available only for the indoor unit adopting the individual louver. The each louver angle can be set individually.

i) NOTE

- This function is available only when the indoor unit corresponds to the individual louver.
- This function cannot be set when the unit is stopped.
- The fan speed will be changed to "LOW" while this function is being set. (After the setting is completed, the unit operation will be back to normal).
- As for "Start-up of Heating Operation", "During Defrost Operation" and "Activation of Thermo-Controller", all the louver angles will be fixed at horizontal position automatically even when this function is activated.
- This function will not be available if 2 (two) remote control switches (including multifunctional remote control switch + wireless remote control switch) are used.
- With one multifunctional remote control switch, the maximum of 4 (four) indoor units can be set for this function.

28

3 Select "Yes" by pressing "⊲" or "▷" and press "OK". The schedule ON/OFF setting will be confirmed and the screen will return to the normal mode.

"(-)" will be turned on when the setting of schedule operation is valid.

" \bigcirc " will be turned off when the setting of schedule operation is invalid.



When the setting of schedule operation is invalid, the schedule operation will not be activated.

1 Select "Louver Setting" from the menu and press "OK".

The individual louver setting menu will be displayed.



 Select "Louver Setting" from the individual louver setting menu and press "OK".

Louver Setting
Louver Setting
Cancel INDV Louver SET
SEL. OK ENT. SRTN.

If the number of indoor unit connected with the remote control switch is 1 (one), (4) will be displayed after the procedure (2).

Select the indoor unit to change the louver direction by pressing "∆", "√", "√" or "▷". Press "OK".

Louver S	etting		
01-01			
01-02			
01-03			
01-04			
	Select u	nit to set.	
SEL.		OK ENT	: 🕤 RTN

i) NOTE

The indoor unit displayed on the screen flashes if the individual louver is set.

4 Press "⊲" or "▷" and select the louver from 1 to 4. The selected louver is opened and the other louvers are closed.



5 Select the louver angle by pressing "∆" or "∇" and press "OK". The confirmation screen will be displayed.



The louver angle will be changed as follows.



6 Select "Yes" by pressing "<]" or "▷" and press "OK". The setting is confirmed and the screen will return to the normal mode.



7 Ensure that "INDV" is turned on at the air flow section on the normal mode.



14.6.2 Cancellation of louver setting

1 Select "Louver Setting" from the menu and press "OK".



2 Select "Cancel INDV Louver SET" from the individual louver set and press "OK".

Louver Setting
Louver Setting
Cancel INDV Louver SET

If the number of indoor unit connected with the remote control switch is 1 (one), (4) will be displayed after the procedure (2).

 Select the indoor unit to cancel by pressing "∆", "√", "√" or "▷". Press "OK". The confirmation screen will be displayed.

Cancel IN	IDV Louve	er SET	
01-01			
01-02			
01-03			
01-04			
	Select uni	t to cancel	
SEL.		OK ENT	S STN.

i NOTE

The indoor unit displayed on the screen flashes if the individual louver is set.

4 Select "Yes" by pressing "< or "▷" and press "OK". The individual louver setting will be cancelled and the screen will return to the normal mode.

Cance	el INDV Louve	er SET:01-03
	Cancel indiv	idual louver?
	Yes	No
SEL.		OK ENT. 🕤 RTN.

|--|

All the individual louver setting will be cancelled.

14.7 LOUVER OPEN/CLOSE

This function is used to fully open louver for adjusting the vertical deflector for air flow direction (manually).

- This function cannot be set when the unit is operated.
- 1 Select "Louver Open/Close" from the menu and press "OK".





2 Select "Yes" by pressing "<! or "▷" and press "OK". The louver will be open (closed) and the screen will return to the normal mode.



Ι ΝΟΤΕ

Refer to Installation & Operation Manual for Indoor Units regarding the adjustment of air flow direction.

14.8 VENTILATION

♦ Function

A/C (Air Conditioning):

To operate the air conditioner individually.

• VENTI (Ventilation):

To operate the total heat exchanger individually.

• A/C+VENTI:

To operate the air conditioner and the total heat exchanger together.

i) NOTE

This function is available only when the total heat exchanger is connected.

1 Select "VENTI" from the menu and press "OK".



Menu	15:10(F	ri)
Louver Setting	3	•
Louver Open/	Close	02
VENTI		/
Total Heat Exc	changer SET	03
Motion Sensor	r Setting	•
SEL.	OK ENT. 5 R	TN.

2 By repeatedly pressing "<" or "▷", the indication is changed in order of "A/C", "VENTI" and "A/C + VENTI". Select the operation target and press "OK". The confirmation screen will be displayed.



3 Select "Yes" by pressing "<" or "▷" and press "OK". The setting will be confirmed and the screen will return to the normal mode.





14.9 SETTING OF TOTAL HEAT EXCHANGER

This function is used to change the ventilation mode of the total heat exchanger.

i NOTE

This function is available only when the total heat exchanger is connected. This function cannot be set when the unit is operated.

1 Select "Total Heat Exchanger SET" from the menu and press "OK". The total heat exchanger set will be displayed.



2 By repeatedly pressing "⊲" or "▷", the indication is changed in order of AUTO VENTI ↔ THEX VENTI ↔ Normal VENTI. Select the operation target and press "OK". The confirmation screen will be displayed.

14.10 MOTION SENSOR

This function is available only when the motions sensor is equipped with the air panel.

The motion sensor detects a human activity by the change of the infrared light.

This function saves the air conditioning capacity (adjusting the set temperature, the air flow volume and the air flow direction) automatically depending on a situation.

The operation after the motion sensor detects as absence can be selected from "Running", "Stand-by" or "Stop" on the remote control switch with the capacity saving.

This setting is available only for the air panel with motion sensor.

\triangle caution

- Do not use the motion sensor function when a baby or a handicapped person stays by oneself. The motion sensor may detect as absence and the operation may be stopped in the case of staying for long time with a bit motion.
- The motion sensor detects the human activity. However, if someone is in a room with a bit motion, the motion sensor may detect as absence.
- The motion sensor may detect as human activity if the indoor unit with the motion sensor is installed near a moving object (ex. swing operation of a heating appliance) which is difference in temperature against atmosphere.
- In the case that the indoor units are operated by 2 remote control switches, the motion sensor setting is available only from the main remote control switch.



3 Select "Yes" by pressing "<]" or "▷" and press "OK". The setting will be confirmed and the screen will return to the normal mode.



- The indoor unit operation can be stopped by the motion sensor control.
- While the air conditioning capacity is saved or the operation is stopped by the motion sensor control, "Motion sensor is activated" is displayed on LCD.
- If the function "Prohibiting operation by remote control switch" is used from the centralized controller, select the command "Running" or "Stand-by" in "If absent" at the motion sensor control setting.
- If "Stop" is selected, the motion sensor control can not be performed correctly as follows:
 - In the case that "Stop" is selected in the motion sensor control setting and "Prohibiting operation by remote control switch" (for all items) is set by the centralized controller, the operation will not be stopped even if the motion sensor control function changes to the stoppage condition.
 - In the case that "Stop" is selected in the motion sensor control setting and "Prohibiting operation by remote control switch" (for part of items) is set by the centralized controller, the indoor unit operation can not be restarted from the centralized controller although the operation can be stopped under the stoppage condition by the motion sensor control function.

14.10.1 Details for motion sensor control

The motion sensor control adjusts automatically the following items depending on a situation.

• Setting Temperature:

The temperature is adjusted 1oC or 2oC for saving capacity.

Air Flow Volume:

The air flow volume is adjusted to lower one volume or to "Slo" (except during the dry operation).

• Air Flow Direction:

The air flow direction is adjusted to horizontal.

14.10.2 Descriptions for setting items

Motion sensor setting:

- ON: The operating control function by the motion sensor is activated.
- OFF: The operating control function by the motion sensor is not activated.

(The default setting is "ON".)

If absent

"If absent" is set for the indoor unit operation after the motion sensor detects as absence for set time in "Check interval". The operation can be selected from "Running", "Stand-by" or "Stop" on the remote control switch.

(The default setting is "Running".)

• Running:

The operation is continued with saving the capacity after detected as an absence.

If the human activity is detected for a period of time, the normal operation will be performed again.

• Stand-by:

The operation mode is the fan operation at "Slo" speed. If the human activity is detected for a period of time, the normal operation will be performed again.

Stop:

The operation is stopped by the remote control switch when all the indoor units with motion sensor detect absence which are connected with same remote control switch. If the human activity is detected for a period of time by the stoppage, the normal operation is performed again.

Check Interval

When the motion sensor detects an absence at selected check interval time, the function "If absent" will be executed. The interval can be selected from 30, 60, 90 120 or 180 minutes.

(The default setting is 30 minutes.)

14.10.3 Setting of motion sensor

 Press "☴" (menu). Select "Motion Sensor Setting" from the menu by pressing "∆" or "∇" and press "OK".



2 "Motion Sensor Setting" is displayed. The highlighted item is shifted to "Sensor", "If absent" and "Check interval" by pressing "∆" or "∇".



To set "Sensor", move to procedure (3). To set "If absent", move to procedure (5). To set "Check interval", move to procedure (7).

3 Press " Δ " or " ∇ " and select "Sensor".



4 The display is switched "ON" and "OFF" in order by pressing "⊲" or "▷" and change the setting.

If other settings are not required, move to procedure (9).



5 Press " Δ " or " ∇ " and select "If absent".



ENGLISH

Inspire the Next

The display is switched "Running", "Stand-by" and "Stop" in 6 order by pressing " \triangleleft " or " \triangleright " and change the setting.

If other settings are not required, move to procedure (9).



7 Press " Δ " or " ∇ " and select "Check interval".



The display is switched "30MIN", "60MIN", "90MIN", "120MIN" 8 and "180MIN" in order by pressing "<?" or "▷" and change the setting.

ON

30MIN

If other settings are not required, move to procedure (9).



14.11 ADJUSTING DATE/TIME

This function is used to adjust the date and time.

Periodic time setting is recommended. (Clock accuracy: difference within ±70 seconds by month).

As for this remote control switch, the clock can work up to 72 hours when power failure occurs. Reset the date and time if the remote control switch remains without power supply for longer than 72 hours or main power supply is OFF for long time.

Select "Adjusting Date/Time" from the menu and press "OK". 1



- Press "⊲" or "⊳" and select "yy/mm/dd/hh/mm". 2
- Press " Δ " or " ∇ " to change the setting. Press or keep pressing 3 " Δ " or " ∇ " to adjust numbers.

Press "OK" after the setting is completed. The confirmation 9 screen will be displayed. Select "Yes" by pressing "⊲" or "▷" and press "OK". The motion sensor setting will be confirmed and the screen will return to the normal mode (operation mode indication).



4 After the setting is completed, press "OK" and the confirmation screen will be displayed.



5 Select "Yes" by pressing "⊲" or "▷" and press "OK". The setting will be confirmed and the screen will return to the normal mode.





•

03

14.12 LANGUAGE SETTING

This function is used to change the displayed language.

1 Select "Screen Display Setting" from the menu and press "OK".



 Select "Language Setting" by pressing "∆" or "∇" and press "OK". The language setting will be displayed.



3 Press " Δ " or " ∇ " to select the language and press "OK". The confirmation screen will be displayed.



4 Select "Yes" by pressing "<" or "▷" and press "OK". The setting will be confirmed and the screen will return to the normal mode.



1 ΝΟΤΕ

If displayed language is changed, the registered room name and contact information will be deleted.

14.13 TEMPERATURE UNIT

This function is used to change the temperature unit.

1 Select "Screen Display Setting" from the menu and press "OK".



2 Select "Temperature Unit" by pressing " Δ " or " ∇ " and press "OK".



34

3 By repeatedly pressing "<" or "▷", the indication is changed in order of "Degrees C" and "Degrees F". Select the operation target and press "OK". The confirmation screen will be displayed.



4 Select "Yes" by pressing "⊲" or "▷" and press "OK". The setting will be confirmed and the screen will return to the normal mode.





Ч С

14.14.1 Display Adjustment

♦ Function

• Time Format:

To change the time form to 12 hour or 24 hour.

Brightness:

To adjust the brightness of backlight.

Back light:

To change the time (5, 15 or 30 seconds) between ON and OFF of backlight.

Contrast:

To adjust the degree of difference between light and dark parts of LCD.

• On/Off lamp (Run Indicator Lamp Brightness):

To adjust the brightness of run indicator.

1 Select "Screen Display Setting" from the menu and press "OK".



2 Select "Display Adjustment" by pressing " Δ " or " ∇ ".



3 Select the setting item by pressing "∆" or "∇". The indication is changed in order of "Time Format", "Brightness", "Back light", "Contrast" and "On/Off lamp"



- 4 Press " \triangleleft " or " \triangleright " and set the display.
- Time Format:

The time form is changed as follows; 12 Hour ← 24 Hour

Brightness:

Press " \triangleleft " or " \triangleright " and the brightness of backlight is changed.

Back light:

The display backlight is OFF after the specified time interval of inactivity (no input from touch screen). The backlight off time interval can be selected as follows;

5 Seconds ↔ 15 Seconds ↔ 30 Seconds

Contrast:

Press " \triangleleft " or " \triangleright " and the degree of difference between light and dark parts of LCD is changed.

• On/Off lamp:

Press " \triangleleft " or " \triangleright " and the brightness of run indicator is changed.

After the setting is completed, press "OK". The confirmation screen will be displayed.



5 Select "Yes" by pressing "< " or "▷" and press "OK". The setting will be confirmed and the screen will return to the normal mode.</p>





14.15 ROOM NAME REGISTRATION

This function is used to register the name of the room (installation location of remote control switch)

1 Select "Room Name" from the menu and press "OK".

The room name will be displayed.



03

1

03

•

By pressing "?" (help), the letter type is changed. 2



Press " Δ ", " ∇ ", " \prec " or " \triangleright " and select the letter. Press "OK" to 3 confirm the selected letter. (Max. 12 letters)

15 HELP MENU

15.1 HELP MENU

The explanation of indicators on LCD and operations can be found in the help menu.

The purpose of this function is to support manual operation.

Refer to the following sections for more details.

1 Press "?" (help).

The help menu will be displayed.





Select the item from the help menu by pressing " Δ " or " ∇ " and 2 press "OK".



Select "FIN." by pressing " Δ ", " ∇ ", " \triangleleft " or " \triangleright " and press "OK". 4 (or simply press "=" (menu)). The confirmation screen will be displayed.



Select "Yes" by pressing "⊲" or "▷" and press "OK". The set-5 ting will be confirmed and the screen will return to the normal mode.





To return to the normal mode, press "≦" (return). 3





NOTE

If the menu screen remains unchanged for approximately 10 minutes, the screen will automatically return to the normal mode.

This function is used when the explanation of each icon on LCD is required.

1 Select "About Indication" from the help menu and press "OK". The explanation of indicators on LCD will be displayed.



2 Press " Δ " or " ∇ " to scroll the text up and down.



3 Press ">" (return). The screen will return to the help menu.

To return to the normal mode, press "≦" (return) again.



15.3 ABOUT OPERATION

This function is used when the explanation of operations and operation methods is required.

1 Select "About Operation" from the help menu and press "OK". The explanation of operation list will be displayed.



2 Select the operation from the list by pressing "∆" or "∇" and press "OK". The explanation of the selected operation will be displayed.



Filter Sign Reset Cleaning Sign Reset Time Setting	Standard Ope	ration
Cleaning Sign Reset Time Setting Screen Display Setting	Filter Sign Res	set
Time Setting	Cleaning Sign	Reset
Screen Display Setting	Time Setting	
Screen Display Setting	Screen Displa	y Setting

3 Press " Δ " or " ∇ " to scroll the text up and down.

	III O ∿ O
--	--------------

About Operation	
Standard Operation RUN/STOP	▲ 01
1. Press the "①" (RUN/STOP) switch The Run Indicator is turned ON	n / 03
during operation. ● Next Page	S RTN.

4 Press "≦" (return). The screen will return to the operation item.





5 Press " \mathfrak{D} " (return). The screen will return to the help menu.

To return to the normal mode, press "≦" (return) again.



HITACHI

Inspire the Next

15.4 TROUBLESHOOTING

This function is used to troubleshoot.

Make sure that the troubleshooting is read carefully before requesting for repairs.

1 Select "Troubleshooting" from the help menu and press "OK". The list of troubleshooting will be displayed.



2 Select a problem from the list by pressing "∆" or "∇" and press "OK". The details of the selected problem will be displayed.



3 Press " Δ " or " ∇ " to scroll the text up and down.



 Unit does not operate. Condition: [<u>HOT-ST</u>] is indicated on the display of the remote comtrol switch. Cause: The control to heat compressor is activated in order to extend the life of the product. 	01 / 06
--	---------------

4 Press "≦" (return). The screen will return to the list of troubleshooting.





5 Press "">" (return). The screen will return to the help menu.

To return to the normal mode, press "≦" (return) again.



15.5 CONTACT INFORMATION

The screen will display contact information and the latest alarm code.

1 Select "Contact Information" from the help menu and press "OK". The contact information and the latest alarm code will be displayed.



2 Press "≦" (return). The screen will return to the help menu.

To return to the normal mode, press "≦" (return) again.



16.1 IN NORMAL CONDITION

16.1.1 Central control

"Central Control" is turned ON.

In case that the prohibiting operation by remote control switch is set from the central controller, operation, temperature setting, fan speed and direction setting are not available from the remote control switch.



16.1.2 Motion sensor control

"Motion sensor is activated" is turned ON during the motion sensor control. In this case, the operation is performed with saving the capacity or stopped by the motion sensor control.



16.1.3 Thermo-controller

The fan speed is changed to "LOW" at the thermo-controller actuation. However, the indication is not changed. (Only in the heating operation mode).

16.1.4 Defrost

Defrost Operation

"DFR" is turned ON during the defrosting.

The indoor fan is stopped though the indication is not changed. The louver is fixed at the horizontal position. However, the louver indication of LCD continues to activate.



Operation Stoppage during Defrosting Operation

The RUN indicator (Green) is turned OFF when the operation is stopped during the defrosting.

However, the operation continues with "DFR" indication, and the unit is stopped after the defrost operation is finished.

16.1.5 Operation control

Supplying Electrical Power

"HOT-ST" is turned ON when the electrical power is turned ON.

In this case, the compressor is under preheating. The operation may not be available for max 4 hours. Do not turn off the outdoor unit electrical power during the high season for Cooling/Heating operation.



• During Hot Start (Heating Operation Only) "HOT-ST" is turned ON.



• Different Operation Mode

The operation mode set by the remote control switch is different with the outdoor unit operation mode.

(Except for the heat recovery system models.)

The indication of the actual operation mode flashes.



Indication when "COOL" operation is set by the remote control switch at the outdoor unit "HEAT" operation.

16.2 IN ABNORMAL CONDITION

16.2.1 Abnormality

The RUN indicator (Red) is flashing.

The indoor unit number, the alarm code, the model code, *model name (Ex. RCI-3.0FSN3) and the connected number of indoor units are displayed on LCD.

(*The unit model name is only displayed for the corresponding unit model.)

In case that the plural indoor units are connected, the above items for each indoor unit are displayed one by one.

16.2.2 Power failure

All the indications are OFF.

Once the unit is stopped by the power failure, the unit will not be started again although the power recovers. Perform the starting procedures again.

In case of instantaneous power failure within 2 seconds, the unit will be started again automatically.

16.3 ALARM CODES

16.2.3 Electric noise

There could be a case that all the indications are OFF and the unit is stopped. This is occurred by the activation of the micro computer for the unit protection from the electric noise.

Perform the starting procedures again.

Code number	Category	Abnormality	Cause	Available for
01	Indoor unit	Activation of the safety device	Failure of fan motor, drain discharge, PCB, relay, float switch activated	All units
02	Outdoor unit	Activation of the safety device	Failure of fan motor, drain discharge, PCB, relay, float switch activated	All units
03	Transmission	Abnormal transmission between outdo- or and indoor units	Incorrect wiring, failure of PCB, tripping of fuse, power supply OFF	All units
04		Abnormal transmission between inver- ter PCB (DIP-IPM) and outdoor unit PCB (PCB1)	Abnormal transmission between PCB	All units
04.		Abnormal transmission between fan controller and outdoor PCB	Fan controller - Outdoor PCB transmission fault (loo- se connector, broken cable, blown fuse)	SET-FREE FSXN
05	Power supply	Abnormal operation of picking up phase signal	Main power supply phase is reversely connected or one phase is not connected	All units
06	Voltago	Excessively low voltage or excessively high voltage for the inverter	Incorrect wiring or insufficient capacity of power supply wiring	All units
06.	Voltage	Abnormal fan controller voltage	Outdoor voltage drop, insufficient power	SET-FREE FSXN
07		Decrease in discharge gas superheat	Discharge gas superheat less than 10 degrees is maintained for 30 minutes.	All units
	Cycle	Executively high discharge gas temps	Temperature of top compressor: Td	
08		rature at the top of compressor	Td > 132°C over 10 minutes, or Td >140°C over 5 minutes	All units
09	Fan motor	Activation of protection device for out- door fan	Fan motor overheat, locking	SET-FREE FSN2
0A	Transmission	Abnormal transmission between outdo- or and indoor unit	Incorrect wiring, broken cable, loose terminals	SET-FREE FSXN
0b	Outdoor upit	Incorrect outdoor unit address setting	Duplicate address setting of outdoor units (secondary units) in the same refrigerant system	SET-FREE FSXN
0C		Main unit of the outdoor unit incorrectly set	Two or more outdoor units defined as the "main unit" in the same refrigerant cycle system	SET-FREE FSXN

Code number	Category	Abnormality	Cause	Available for
11	Sensor on indoor unit	Air inlet thermistor		All units
12		Air outlet thermistor	Failure of thermistor, sensor, connection.	All units
13		Freeze protection thermistor		All units
14		Gas piping thermistor		All units
15	Econofresh	Abnormal operation of thermistor for fresh outdoor air		SET-FREE MINI
16		Remote thermistor	Failure of thermistor	SET-FREE MINI
17	Sensor on indoor unit	Thermistor of RCS	Failure of thermistor	SET-FREE MINI
19		Activation of the protection device for the indoor fan motor	Failure of fan motor	All units
20		Compressor thermistor	Failure of thermistor, sensor, connection.	RASC IVX
21		High pressure sensor	Incorrect wiring, disconnected wiring, broken cable, short circuit.	SET-FREE MINI
22		Thermistor for outdoor ambient tempe- rature (THM7)	Failure of thermistor, sensor, connection.	All units
23	Sensor on outdoor unit	Thermistor for discharge gas tempera- ture (THM9)	Incorrect wiring, disconnected wiring, broken cable, short circuit.	SET-FREE MINI
24		Thermistor for evaporating temperature (THM8)	Failure of thermistor, sensor, connection.	All units
25		Heat exchanger gas pipe thermistor	Incorrect wiring, disconnected wiring, broken cable,	SET-FREE FSXN
29		Low pressure sensor	short circuit	SET-FREE MINI
31		Incorrect capacity setting or combined capacity between outdoor and indoor units	Incorrect setting of the capacity code.	All units
35	System	Incorrect indoor unit number setting	Duplication of indoor unit number , number of indoor units over specifications.	All units
36		Incorrect indoor unit combination	R22 indoor unit	SET-FREE MINI
38		Abnormality of picking up circuit for protection (Outdoor unit)	Failure of indoor unit PCB, incorrect wiring, connection to PCB in indoor unit.	All units
39	Compressor	Abnormal operation current in constant speed compressor	Overcurrent, blown fuse, current sensor fault, instant power failure, voltage drop, abnormal power supply	SET-FREE FSXN and FSN2
3A		Abnormal outdoor unit capacity	Outdoor unit capacity >54HP	SET-FREE FSXN
3b	Outdoor unit	Voltage or combination of outdoor unit models incorrectly set	Voltage or combination of secondary and main units incorrectly set	SET-FREE FSXN
3d		Abnormal transmission between the main unit and the secondary unit(s)	Incorrect wiring, disconnected wiring, broken cable, PCB fault	SET-FREE FSXN
41	Pressure	Cooling overload (possible activation of high pressure device)	If the outdoor unit pipe thermistor temperature is higher than 55°C and the compressor top temperatu- re is higher than 95°C, outdoor unit pretection device is activated.	RASC IVX
42		Heating overload (possible activation of high pressure device)	If the indoor unit freeze protection thermistor tempe- rature is higher than 55°C and the compressor top temperature is higher than 95°C, outdoor unit pretec- tion device is activated	RASC IVX
43		Activation of the safety device from com- pression ratio decrease	Abnormal compress (Compressor, Inverter damage)	SET-FREE MINI
44		Activation of the safety device from excessively high suction pressure	Overload during cooling, high temperature with hea- ting, loked expansion valve	SET-FREE MINI
45		Activation of the safety device from excessively high discharge pressure	Overload (obstruction of HEX, short circuit) mixture of inert gas	SET-FREE MINI
47		Activation of the safety device from excessively low suction pressure (pro- tection from vacuum operation)	Shortage or leakage of refrigerant, piping clogging, expansion valve close-locked, fan motor locked.	All units

Code number	Category	Abnormality	Cause	Available for
48	Inverter	Abnormality of current sensor for in- verter	Failure of DIP-IPM, heat exchanger clogged, locked compressor, EVI/EVO failure or overcharge.	All units
51		Abnormality of Current Sensor for In- verter	Failure of control PCB, inverter module.	All units
53		Protection activation of inverter module	Inverter module abnormality.	All units
54		Inverter fin temperature increase	Abnormal inverter fin thermistor, clogging of heat exchanger, abnormal outdoor fan.	All units
55		Inverter Module abnormality	Failure of inverter module.	All units
56	Outdoor fan	Abnormal detection of fan motor posi- tion	Abnormal of fan motor position detection circuit, dis- connected wiring	SET-FREE FSN2
57		Fan Motor abnormality	Disconnected wire of incorrect wiring between control PCB and inverter PCB.	SET-FREE MINI
			Incorrect wiring or fan motor abnormality.	
58		Abnormal fan controller	Abnormal operation speed	SET-FREE FSN2
5A	Fan controller	Abnormal fan controller fin temperature	Fin thermistor fault, heat exchanger clogging, fan motor fault	SET-FREE FSXN
5b		Overcurrent protection activation	Fan motor fault	SET-FREE FSXN
5C		Abnormal fan controller sensor	Current sensor fault (instant overcurrent, increased fin temperature, low voltage, earthing fault, step-out)	SET-FREE FSXN
b1	Indoor unit	Incorrect setting of the unit and the refrigerant cycle number.	Over 64 indoor units setting by number or indoor unit address.	All units
b5	number setting	Incorrect indoor unit connection number setting	There are more than 17 units not corresponding to H-Link II connected to one system	SET-FREE MINI
C1	CH unit	Incorrect indoor unit connection	There are 2 or more CH units connected between the outdoor and indoor units	SET-FREE FSXN
C2		Connection number of the indoor unit incorrectly set	There are 9 or more indoor units connected to the CH unit	SET-FREE FSXN
C3		Incorrect indoor unit connection	Indoor units from different refrigerant cycles have been connected to the CH unit	SET-FREE FSXN
EE	Compressor	Compressor protection	Failure of compressor.	All units